

439

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/193

Dated. 05/07/2022

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Tumble House Entertainment LLP** located at E-20, Defence, New Delhi- 110024 comprised of Basement, Ground + Three Upper Floors but the **recreation Centre & Coffee House running at Ground floor only** owned/occupied by M/s Tumble House Entertainment LLP was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2019/SZ/2131 dated 13/11/2019. The restaurant premise was re-inspected by the officer concerned of this department on 27/06/2022 in the presence of Sh. Karan Batra (Director) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Recreation Centre & Coffee House)** with effect from 05/07/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/07/2022 at New Delhi by

  
**(SUNIL CHAUDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**  
**DELHI FIRE SERVICE**

Copy to: -

1. The Joint C.P (Lic) 1<sup>st</sup> Floor, PS Defence Colony, New Delhi 110049. (ref. MHA Portal ID 2022051310141 dated 13/05/2022)
2. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-16.
3. M/s Tumble House Entertainment LLP located at E-20, Ground Floor, Defence, New Delhi 110024.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."



## INSPECTION REPORT

1	Name & Address of the Building	M/s Tumble House Entertainment LLP at E-20 , Ground Floor, Defence, New Delhi 110024		
2	Type of Occupancy	Group-D, "Assembly"		
3	Building Comprised of	Basement + Ground + Three upper floors but the recreation centre & Coffee house at Ground floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/2131 dated 13/11/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	27-06-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Karan Batra (Director)		
10	Year of construction	2011		
11	Applicant letter No.	MHA Portal 2022051310141 dated 13/05/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	As per MPD-2021 N/A N/A	06 mtr N/A N/A	MR N/A N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	a) Number of Staircase			
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2m & 1.50m	2m (two) & 1.50m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	Required Required N/A N/A N/A	Provided Provided N/A N/A N/A	MR MR N/A N/A N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground floor</li> </ul>	N/A 12 ACPH	N/A Provided	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	08 ABC/CO2 Required	08 Nos ABC & CO2 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	One 30m 5mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A





8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors/ Restt. Area	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby Pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➢ Pump house access.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➢ Discharge of pump.	450 LPM	Provided	MR
	➢ Head of pump.	40m	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for firefighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	Required	Provided	MR
	➢ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltr	20,000 ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	<b>Fire Control Room.</b>			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A



The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/2131 dated 13/11/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

14/11/2022

Signature of the Inspecting Officer  
Name: Rajesh Kumar  
Designation: ADO / BCP

DO (SD)

14/11/2022

DFO (SZ)

J. K.

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

14/11/2022

Dy CSE/2

h

M.S. up

uploaded

up  
or  
electron