

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/2022/School/WZ/ 783

Dated: 26/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **Adarsh Senior Secondary School, Libaspur, G.T. Road, Delhi-42**, comprised of **Ground + One upper floor** owned/occupied by **Adarsh Senior Secondary School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2018/School/197 dated 31.01.2018**. The premises was re-inspected by the officer concerned of this department on **08.07.2022** in the presence of **Sh. Ishwar Lal (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...26.7.22... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on26/7/22... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Adarsh Senior Secondary School, Libaspur, G.T. Road, Delhi-42.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

1. Name & address of the building : Aarsh Senior Secondary School, Libaspur, G.T. Road, Delhi-42.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 01 upper floor)
4. Details of Previous NOC : E.P. DFS/MS/2018/School/197 dated 31.01.2018.
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011.
6. Date of inspection : 17.03.2022
7. Name of Inspecting Officer : Anil Kumar Sharma ADO(Rohini)
8. Name and designation of officers:
From the building side : Anil Kumar Lal (Principal)
9. Year of Construction : 2007
10. Applicant's letter No : 17/2022 No.7412 dated 17.03.2022.

S. No.	Minimum Standards on fire prevention and fire safety (2021)	Circular of Director of Education	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	Accessible	Accessible	MR
	• Gate width	4.5m	3.60m	MR(Old case)
	• Width of internal road	NA	NA	NA
2.	Number, Type & Arrangement of Exits			
	a. Number of exits			
	• Upper floors	02	02	MR
	• Basement	NA	NA	NA
	b. Width of exits			
	• Upper floors	1.5m	1.68m x 2	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	Fire chime	NA	NA	NA
	• Protection of exits	NA	NA	NA
	d. No. of exits from each floor	NA	NA	NA
	e. Width of exits	Required	2.7m	MR
	f. Door	1m	1.0m	MR
3.	Comparison			
	• Fire escape	NA	NA	NA
	• Fire escape	NA	NA	NA
	• Fire escape	NA	NA	NA
	• Fire escape	NA	NA	NA
	• Fire escape	NA	NA	NA
4.	Smoke			
	• Smoke	0 a/c per hour	NA	NA
	• Smoke	2 a/c per hour	Natural ventilated	MR
5.	Fire Ex			
	• Fire Ex	07nos.	07nos.	MR
	• Fire Ex	ABC/CO2	ABC-7	MR
	• Fire Ex	marked	Yes	MR
6.	First-A			
	• First-A	NA	NA	NA
	• First-A	NA	NA	NA
	• First-A	NA	NA	NA
7.	Auto			
	• Auto	NA	NA	NA
	• Auto	NA	NA	NA
	• Auto	NA	NA	NA
	• Auto	NA	NA	NA
	• Auto	NA	NA	NA

8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

N/12

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2018/School/197** dated **31.01.2018** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Handwritten signature]
11/7/22

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

~~DO (NW)~~

[Handwritten signature]
11/07/2022

~~Dy Cfo (w2)~~

[Handwritten signature]
19/7/2022

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please.

~~Dy Cfo (w2)~~

[Handwritten signature]
25/7/22

[Handwritten signature]
21/7/22

[Handwritten signature]