



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**




No. F6/DFS/MS/School/WZ/2022/786

Dated 26/7/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Guru Harkrishan Public School (Code-20133531)** Located at **G-8, Nihal Vihar, Chander Vihar, New Delhi-110041**, comprised of Basement + Ground + 03 Upper Floors only owned/occupied by **Guru Harkrishan Public School** was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2019/1428 Dated 12.07.2019**. The said premise was re-inspected by the officer concerned of this department on 06.07.2022 in the presence of Ms. Ranjeet Kaur (Principal) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no. 3298-3398 dated 01.03.2011/NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 26/7/22 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 26/7/22 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to :-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Guru Harkrishan Public School (Code-20133531), G-8, Nihal Vihar, Chander Vihar, New Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

## INSPECTION REPORT 14-21

1. Name & address of the building : Guru Harkrishan Public School (Code-201335531), G-8, Nihal Vihar, Chander Vihar, New Delhi-110041
2. Type of Occupancy : Educational (Basement+Ground+03 Upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School 2019/1428 dated 12.07.2019
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01.03.2011
6. Date of inspection : 06.07.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Ms. Ranjeet Kaur (Principal)
9. Year of Construction : 2008
10. Applicant's letter no. : email dated 09.06.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ Requirements/ as per FSC dated	Provided at site	Remarks MR/NMR
1.	<u>Access of building</u>			
	• Road width	Accessible	09 m	MR
	• Gate width	Accessible	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	<u>Number, width, Type &amp; Arrangements of exits</u>			
	a. Number of staircases			
	• Upper floors	02	03	MR
	• Basements	02	03	MR
	b. Width of staircases			
	• Upper floors	1.5 m	1.54 m, 1.28m & 1.35m	MR
	• Basements	1.5 m	1.54 m, 1.28m & 1.35m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	<u>Compartmentation</u>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<u>Smoke managements System</u>			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	<u>Fire Extinguishers</u>			
	• Total numbers	16 nos ABC	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	<u>First - Aid Hose Reels</u>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

11-22

7 Automatic fire detection and alarming system			
• Type of detectors	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA
8 MOEFA	NA	Provided	NA
9 Public Address System	NA	Provided	NA
10 Automatic Sprinkler System			
• Basements	Required	Provided	MR
• Upper Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants			
• Size of riser/down-comer	NA	100 mm	NA
• Number of hydrants per floor	NA	01	NA
• Hose Box	NA	01	NA
12. Yard Hydrants			
• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA
13. Pumping Arrangements:			
• Ground Level	NA	NA	NA
• Discharge of main pump	NA	NA	NA
➤ Head of main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Starting/Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace level	NA	NA	NA
➤ Discharge of pump	900 lpm & 180 lpm	Provided	MR
➤ Head of the pump	40 m	Provided	MR
➤ Power supply	Required	Provided	MR
➤ Auto starting of pump	Required	Provided	MR
14 Captive water Storage for fire fighting:			
• Under ground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	15,000 ltrs	Provided	MR
15 Exit Signage	Required	Provided	MR
16 Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17 Standby power supply	NA	NA	NA
18 Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19 Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20 Special Fire Protection Systems for Protection of special Risks, if any.	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/1428 dated 12.07.2019 is recommended.

Accordingly DFA is prepared & put up for approval please.

*Amitha*  
12/7/22  
Aman Kumar Lathar  
ADO (JWP)

~~DO (W)~~

*[Signature]*  
12/02/2022

DO (WEST) 356  
DATED 12/7/2022

~~DO (W2)~~

*[Signature]*  
15/7/2022

~~ADO (W2)~~ F.P. letter is put-up for signature 101.

~~ADO (W2)~~

*[Signature]*  
15/7/2022

*Amitha*  
12/7/22  
ADO (W2)

MS/