



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
C12


No. F6/DFS/MS/School/WZ/2022/ 780

Dated: 26/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **North Delhi M. C. Prys. School** Located at **A-1, Ashok Vihar, Phase-II, Delhi-110052**, comprised of Ground + 01 Upper Floor (**Ground Floor block abandoned**) was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2019/1654 Dated 21.08.2019. The said premise was re-inspected by the officer concerned of this department on 14.07.2022 in the presence of Ms. Geeta Gupta (Principal) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 26/7/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed below.

Issued on 26/7/22 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, North Delhi M. C. Prys. School, A-1, Ashok Vihar, Phase-II, Delhi-110052.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **North Delhi M. C. Pry. School Located at A-1, Ashok Vihar, Phase-II, Delhi-110052.**
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
(Old Block, Ground floor Only abandon)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/1654 Dated 21.08.2019
5. Fire Safety directives Letter No : D.O.E Circular no 3298-3398 dated 01-03-2011
6. Date of inspection : 14.07.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Ms. Geeta Gupta (Principal)
9. Year of Construction : 2014
10. Applicant's letter No : email dated 20.06.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	D O E Circular No. 3298-3398 Dated 16.04.2019/ as per FSC dated 21.08.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 280 cm NA 	<ul style="list-style-type: none"> MR MR(Old Case) NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 02 NA 1.5 m each NA NA NA NA 01 1.5 m 1 m 	<ul style="list-style-type: none"> Provided NA 180 cm x 1 & 150 cm x 1 NA NA NA NA Provided 210 cm 110 cm Provided (Double door) 	<ul style="list-style-type: none"> MR NA MR NA NA NA MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA

21-6

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos ABC & CO ₂ ISI marked	10 nos. Provided Provided	MR MR MR
6	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

[Handwritten signature]

17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/2019/1654 Dated 21.08.2019 is recommended.

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
18/7/22
Aman Kumar Lathar
ADO (JWP)

~~DO (W)~~

~~dy 18/7/22~~

~~DFS (WZ)~~

~~19/7/22~~

~~ADO (JWP)~~

FT. letter is put-up for signature pl.

~~DO (WZ)~~

~~20/7/22~~

Aman Kumar Lathar
20/7/22
ADO (WZ)

~~MS/ cell~~

DO (WEST) SBA
DATE: 18/7/22