

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Hostal/2022/SZ/ 332

Dated: 26/07/2022

FIRE SAFETY CERTIFICATE

Certified that “**Block No 3**” (Hostal No 17) at **AIIMS Ansari Nagar, New Delhi 110029** Comprised of Two Level Basement (for Parking, Service and Storage) Ground plus Five Upper Floors owned/occupied by All India Institute of Medical Science was issued FSC by this department vide letter F6/DFS/MS/2015/SZ/62 dated 12/01/2015. The premise was re-inspected by officer concerned of this department on 12/07/2022 in the presence of Mr. Ashok Kumar Sharma (Fire Officer) and the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Residential Building Group-A**” (Hostel) with effect from 26/07/2022 for period of **Five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 26/07 / 2022 at New Delhi by


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Mr. Satyendra Kumar, Chief Security Officer, AIIMS, Administrative Block, New Delhi

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.”

N/39



INSPECTION REPORT

1	Name & Address of the Building	Block No 3, (Hostal No 17) AIIMS Ansari Nagar, New Delhi 110029		
2	Type of Occupancy	Residential, "Group A"		
3	Building Comprised of	Two Level Basement (for Parking, Service and Storage) Ground plus Five Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2015/SZ/62 dated 12/01/2015		
6	Fire Safety Directives Letter No	F 6/DFS/MS/BP/2017/44 dated 20/02/2017		
7	Date of online Inspection	12-07-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ashok Sharma (Fire Officer)		
10	Year of construction	2014		
11	Online Applicant letter No.	Outdoor diary no 7633 dated 25 03 2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	08 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	06 mtr	06 mtr	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 Nos	Provided	MR
	➤ Basement floor	02 Nos + 02 ramp	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr (each)	1.50 mtr each	MR
	➤ Basement floor	1.50m each SC + 05 mtr each ramp	1.50m each SC + 05 mtr each ramp	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	Required 02 No's	Provided	MR
	e) Width of corridor	1.5 m	Provided	MR
	f) Door size	1.0 mtr	1.0 mtr	NMR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	Required	Provided	MR
	• Fire dampers.	Required	Provided	MR
4	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI marked	Hostel 36 No's	MR
	• Types		ABC, CO2 & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose-reels	02 at each floor	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR

N/40

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooter's location 	Required	Provided	MR
		Required	Provided	MR
		All areas	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		02 Nos	Provided	MR
		02 Nos	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	04 Required	Provided	MR
		04 Required	Provided	MR
13	Pumping arrangements.	Common for all three hostels buildings and dining hall		
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping Pump House Access 	2280 + 2850 LPM	Provided	MR
		65+40m	Provided	MR
		2+1	Provided	MR
		180+280 LPM	Provided	MR
		65	Provided	MR
		2280 LPM	Provided	MR
		65m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	NA	900 LPM	NA
		NA	40 m	NA
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	2,00,000 ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/41

19	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/2015/SZ/62 dated 12/01/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten signature]
15/7/22

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/BCP

Dy. CFO (SZ) | on leave

G. A/c
[Signature]
21/7/2022
Director
[Signature]
21/7/22

ADDO
[Signature]

As approved, F-1 letter is put up for
your signature P/

[Handwritten signature]
21/7/22

Director
[Signature]
25/7/22
[Signature]