

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2022/WZ/ 331

Dated: 26/07/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Horizon Industrial Products Pvt. Ltd. Plot No.B-4, Badli, Industrial Estate, Delhi-42**, comprised of **Ground + Mezzanine & 01 upper floor** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/WZ/502 dated 26.03.2018**. The premises was re-inspected by the officer concerned of this department on **08.07.2022** in the presence of **Mr. Abhijit Dutta** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **G-2, Industrial** with effect from _____ for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to :-

1. M/s Horizon Industrial Products Pvt. Ltd. Plot No.B-4, Badli, Industrial Estate, Delhi-42.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : M/s Horizon Industrial Products Pvt. Ltd. Plot No.B-4, Badli, Industrial Estate, Delhi-42.
2. Type of Occupancy : G-2 Industrial
3. Type of Case : Renewal (**Ground + Mezzanine & 01 upper floor**)
4. Details of Previous NOC : F.6/DFS/MS/2018/WZ/502 dated 26.03.2018.
5. Fire Safety directives letter No : F.6/DFS/MS/87/BP/1989 dated 07.12.1987
F.6/DFS/MS/BP/87/679 dated 09.06.1987
6. Date of inspection : 08.07.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Abhijit Dutta
9. Year of Construction : 1987
10. Applicant's letter No. : Online e-mail dated 19.05.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	9.0m	12m	MR
	• Gate width	4.5m	5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.20m	1.20m & 0.95m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.20m	1.20m	MR
	f. Door Size	1.20m	1.20m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	08nos.	10nos.	MR
	• Types	ABC/CO2	AB-8C/CO2-2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	NA	NA

	<ul style="list-style-type: none"> Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA Required NA	NA Provided NA	NA MR NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	Provided 100mm Provided Provided	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	Provided 02 Provided	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450lpm 40m NA NA	1620lpm NA NA NA NA NA NA NA 900lpm 40m NA NA	NA NA NA NA NA NA NA NA MR MR NA NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000ltr NA NA NA 2500ltr	1,00,000ltr NA NA NA 10,000ltr	MR NA NA NA MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	Provided	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA NA	NA NA	NA NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

2/11

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2018/WZ/502 dated 26.03.2018** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
11/7/22

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

DO (NW)

Ajay
14/07/2022

Dy. CPO (WZ)

[Signature]
19/7/2022

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please.

Dy. CPO (WZ)

[Signature]
28/7/2022

Ajay
20/7/22

ms/ajay