

CS

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ2022/ 795

Dated: 27/07/2022

FIRE SAFETY CERTIFICATE

Certified that building of Sarvodaya Kanya Vidhalaya No-2, (New Block) Located at Palam Village, New Delhi – 110045 (SKV No. 2 School ID – 1821015) & (2nd shift SBV No. 2 School ID – 1821001) having 02 blocks **comprised of G+ 03 Upper Floors** owned/ occupied By **Govt. Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 15/07/2022 in the presence of Sh. Sumit Mishra (HOS) and found that the said building is fit for occupancy class “Educational” Group B Sub Division B – 1 with effect from 27/7/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/7/22 at New Delhi.


(Anul Garg)
Director
Delhi Fire Service.

Note:- The FSC is valid for two new blocks comprised of Ground plus 03 Upper Floors only.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal Sarvodaya Kanya Vidhalaya No-2, (New Block) Located at Palam Village, New Delhi – 110045 (SKV No. 2 School ID – 1821015) & (2nd shift SBV No. 2 School ID – 1821001).

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/20

INSPECTION REPORT

NA

d and found

tion and fire
2015/SZ/646
commended.

1. Name & address of the building: Sarvodaya Kanya Vidhalaya No-2, Located at Palam Village, New Delhi – 110045 (SKV No. 2 School ID - 1821015) & (2nd shift SBV No. 2 School ID – 1821001)
2. Type of Occupancy : Educational Two Blocks (Ground+ 3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : NBC
6. Date of inspection : 15/07/2022
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Sumit Mishra (HOS)
9. Year of Construction : 2020-21
10. Applicant's letter No. :54(SPS School)/PWD Edu.Sub-Divn MI-1(N)2021-22/Camp(01) Dated-24/06/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	Accessible	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	BL-A=170cm, 167cm & 163 cm BL-B=2 X 165 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	150cm	170 cm	MR
	f. Door Size	120cm	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/A			
4.	Smoke managements System		
	• Basements	NA	NA
	• Upper floors	Required	Natural ventilation provided
5.	Fire Extinguishers		
	• Total numbers	01 ABC & CO ₂	Provided
	• Types	For every 300 sq. mtr ISI marked	Provided
	• IS marking		Provided
6.	First – Aid Hose Reels		
	• Total numbers on each floor	02 Each floors	Provided
	• Length of hose reel hose	30m	Provided
	• Nozzle diameter	5mm	Provided
7.	Automatic fire detection and alarming system		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8.	MOEFA	NA	NA
9.	Public Address System	NA	NA
10	Automatic Sprinkler System		
	• Basements	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants:		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA

N/22

13	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm each block	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltrs each block	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

N/23

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADO/DWLR

~~18/7/22~~

~~Dy Sd/O~~ 19/7/22

Dy Sd/O (SU) / on leave

C.F.O 21/7/2022

~~Director~~ 21/07/22

Dy Sd/O 26/7/22

ADO (Dwarka)

Dir AP letter is put up for sign b/c

~~Director~~ 26/07/22

mu

~~18/7/22~~