

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/CNG/2022/SZ/ 337

Dated: 29/07/2022

FIRE SAFETY CERTIFICATE

Certified that **CNG Dispensing Station**, located at **Sunchari Pullah DIMTS Bus Depot, New Delhi** Comprised of **Ground floor only with 02 Dispensers Unit, 02 Cascades Unit and 02 Gas Compressor Unit** owned/occupied by M/s Indraprastha Gas Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officers concerned of this department on 14/07/2022 in presence of Mr. Sandeep Kumar (Manager) and that the building is fit for **occupancy class Storage (CNG Pump)** with effect from 29/07/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/07/2022 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Indraprastha Gas Ltd, Retail Outlet (CNG Pump) at Sunehari Pullah DIMTS Bus Depot.		
2	Type of Occupancy	(CNG Filling Station)		
3	Building Comprised of	Ground floor only (02 Dispensers unit, 02 Cascades unit and 02 Gas Compressor Unit)		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/CNG/2012/2019 dated 01/06/2012		
7	Date of Inspection	14-07-2022		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar (ADO BCP)		
9	Name & Designation of Officers from the building side	Mr. Sandeep Kumar (Manager)		
10	Year of construction	2000		
11	Applicant letter No.	IGL/F&S/2022/15/134/1 Dated 14-07-2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement & letter dt 30/04/2004	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtr 05 mtr -NA-	Provided Provided -NA-	MR MR -NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	01 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	22 nos Required ISI Marked	Co2 Flooding – 45 Kg- 01 Nos, DCP 75 Kg- 06 Nos, & CO2 – 4.5 kg -03 Nos DCP/10 kg- 11 Nos. & CO ₂ – 03 Nos Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

As Per minutes of meeting letter no F2/DFS/HQ/2004/685/D dated 20/04/2004

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	NA	NA	NA
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 	As Per minutes of meeting letter no F2/DFS/HQ/2004/685/D dated 20/04/2004		
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
15.	No Smoking signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
17	Standby Power Supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-

217

श्रीलक्ष्मी
संजय कुमार

19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Co2 flooding system connected through detectors provided in each compressor unit		MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for perusal and signature please.

Signature of the Inspecting Officer
Name: Mr. Rajesh Kumar
Designation: ADO (BCP)

27,

Dy. CFO (SZ)

sh
25/7/2012

C.F.O.
25/7/2012

Director
26/07/12

As approved, F.T.
your signature pl

letter is put up for

28/7/12

Director
29/7/12

✓