

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/CGHS/NDZ/2022/ 336

Dated : 29.07.2022

FIRE SAFETY CERTIFICATE

Certified that the **Habitat CGHS Ltd. at plot no. B-19, Vasundhara Enclave, Delhi-110096** comprises of **Two blocks (Ground + 04 upper floors) & One block (Ground + 08 upper floors)** owned occupied by Habitat CGHS Ltd., was granted NOC by this department vide letter No. F6/MS/DFS/CGHS/2002/270 dated 08.02.2002. The premises was re-inspected by the officers concerned of this department on **14/07/2022** in the presence of Mr. P.K Jain (President) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class A "**Residential Building**" with effect from **29/7/22** for period of **five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 29/07/2022 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

Mr. P.K Jain,
President,
Habitat CGHS Ltd.
B-19, Vasundhara Enclave, Delhi-110096

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/10

INSPECTION REPORT



1. Name & address of the building : Habitat CGHS Ltd. at plot no. B-19, Vasundhara Enclave, Delhi-110096
2. Type of occupancy : Residential Building
Two blocks (Ground + 04 upper floors) & One block (Ground + 08 upper floors)
3. Type of case:- : Renewal
4. Details of previous NOC : F6/MS/DFS/CGHS/2002/270 dated 08.02.2002
5. Fire safety directives No. : F6/DFS/MS/CGHS/96/787 dt. 01/07/1996
6. Date of inspection:- : 14/07/2022
7. Name of the inspecting officer : Sh. A.K Jaiswal (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer : Mr. P.K Jain (President)
9. Year of construction : 1996
10. Applicant's letter No : Email Dated 28/06/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	24 mtr.	MR
	2) Gate width	6 mtr.	6 mtr.	MR
	3) Width of internal road	6 mtr.	6 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 M & 1.0 M	1.25 mtr. X 1 1.0 mtr. X 1	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	E. Width of corridor	1.5 mtr	1.5 mtr	MR
	F. Door size	1 mtr.	1mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	02 hrs	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Provided	MR
	2) Upper floors	Required	Natural	MR

5.	Fire Extinguishers			
	1) Total numbers	35 nos.	40 nos.	MR
	2) Types	ABC & WCO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box each floor	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02 no.	Provided	MR
	2) Hose box	02 no.	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2250 LPM	2250 LPM	MR
	b) Head of main pump	63 mtr.	63 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	180 Lpm	180 Lpm	MR
	e) Jockey pump head	63 M	63 M	MR
	f) Stand by pump output	2250 Lpm.	2250 Lpm.	MR
	g) Stand by pump head	63 M	63 M	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

M

Captive Water Storage for Fire Fighting				
14.	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	Required	Provided	MR
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: LT & HT Panel provided			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/CGHS/2002/270 dated 08.02.2002 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- A DO (LN)

DY. C.F.O. (RDZ)

C.F.O. / 26/7/2022
Director / 26/07/22

Signature of the Inspecting Officer

A.K. Jaiswal
19/07/2022

Name :- A.K Jaiswal
Designation :- DO (ED)

26/07/22

FT PLS

AND/LN

M.K.S
27/7