

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/BNQT/ 36

Dated: 20/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Euphoria Banquet** running at Ground, First & Second Floor in a building comprised of Two Basements, Ground floor, Mezzanine plus two upper floors located at Plot No. F-3, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-110041, owned / occupied by Euphoria Banquet (A unit of Unicorn Celebrators), was granted fire safety certificate by this office vide letter No. F.6/DFS/MS/Banquets/2019/WZ/1055 dated 20.05.2019. The banquet hall was re-inspected by the officer concerned of this department on 02/07/2022 in the presence of Sh. Rajiv Nagpal (Partner) and found that the banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly (Group - D) (for Ground, First & Second Floor only)** with effect from 20/7/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 20/7/2022 at New Delhi.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Gopal Kumar, M/s. Euphoria Banquet, Plot No. F-3, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-110041.
2. The DHO, North Delhi Municipal Corporation, Rohini Zone, Rohini Sector- 05, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of unified building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director through MHA portal <https://delehlhlic.mha.gov.in>
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.
9. **This FSC is valid for Ground, First & Second Floor only.**

N/25

INSPECTION REPORT

Name & address of the building: M/s. Euphoria Banquet, Plot No. F-3, Udyog Nagar,
Industrial area, R ohtak Road, New Delhi-110041

2. Type of Occupancy : Banquet (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Banquets/2019/WZ/1055 Dated 20.05.2019
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2019/784 dated 08.02.2019
6. Date of inspection : 02.07.2022
7. Name of the Inspecting Officer : M. K. Chattopadhyay, DO(West), Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Rajiv Nagpal (Partner)
9. Year of Construction : 2017-18
10. Applicant's letter no. : Online application no. 2022041707306

The said banquet hall is running at ground, first & second floor in a building comprised of 02 basements, ground, mezzanine plus two upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Clause 35 (VI) of DFS Act- 2007	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	As per sanctioned plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	03	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	1 x 2.0, 2x1.5 m	2 m x 2 (01 Iron & 01 Concrete) & 1.5 m	MR
	• Basements	2 x 1.5 m	1 x 2.0, 1 x 1.5 mts	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	3 x 2.0 m	3 x 2.0 m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required for car lift	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	18 nos.	25 nos.	MR
	• Types	ABC, CO ₂ & WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/26

Fire control
De
F
Spec
Pro

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Alternate Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2850 lpm	Provided	MR
	➤ Head of main pump	70 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby Pump out put	2850 lpm	Provided & directly connected with D.G.	MR being old case
	➤ Standby Pump Head	70 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	70 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs	20,000 lts	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

MR

N/27

Fire control room


➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: All the shortcomings pointed out by this department in earlier inspection vide this office letter No. F.6/DFS/MS/WZ/2022/BNQT/90 dated 10.06.2022 have been complied with by the management.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Banquets/2019/WZ/1055 Dated 20.05.2019, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.



#12

M.K. Chattopadhyay,
DO (West)

D.O. (WEST) 380
DATED 11/07/22


11/7/22

Aman Kumar Lathar,
ADO (JWP)



DCFO (WZ)


19/7/2022


PTU


DO (West)

F-T. letter is put up for sign. please.


DCFO (WZ)


20/7/2022


20/7/2022


M.S. Aiy

uploaded

M.