

427



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No F 6 DFS/MS/School/2022/SZ/ 825

Dated: 29/7/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Atul Adarsh Vidyalaya** located at Babu Market, Sarojni Nagar, New Delhi (School ID 2026079) comprised of Ground plus One upper floor owned / occupied by New Delhi Municipal Corporation was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/1882 Dated 01/10/2019. The said premises was re-inspected by officer concerned of this department on 14/07/2022 in presence of Sh. Sunil Kumar (Vice Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 29/7/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 29/7/2022 at New Delhi by

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. Atul Adarsh Vidyalaya at, Babu Market, Sarojni Nagar, New Delhi (School ID 2026079)
2. The Fire Officer, New Delhi Municipal Corporation, Palika Kender, New Delhi 110001

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	Atul Adarsh Vidyalayam, Babu Market, Sarojni Nagar, New Delhi (School ID 2026079)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus one upper floor		
4	Type of Case	Renewal /Name Change		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1882 Dated 01/10/2019		
6	Fire Safety Directives Letter No	F 16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01 03 2011		
7	Date of Inspection	14-07-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Sunil Kumar (Vice Principal)		
10	Year of construction	1973		
11	Applicant letter No	No D-391/AAVSM/22 dated 01/07/2022		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Accessible	9 m	MR
	• Gate width	NA	3.60 m	NA
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	05 nos	05 Nos + 1 Ramp	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m/0.75m	0.93m, 1.01m, 1.05m, 1.60m, 1.62m & ramp 1.37m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e) Width of corridor</b>	1.50 mtr	Provided	MR
	<b>f) Door size</b>	1 mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	12 No	14 Nos	MR
	• Types	ABC	ABC & Co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor	-NA-	-NA-	-NA-
	• Length of hose-reel hose	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			

N/15

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>	-NA-	Provided at GF	-NA-
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose box</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey Pump output</li> <li>Jockey Pump head</li> <li>Standby Pump output</li> <li>Standby Pump head</li> <li>Auto Starting / Manual Stopping</li> <li>Pump house access</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> <li>Discharge of pump</li> <li>Head of pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	-NA-	450 LPM	-NA-
		-NA-	40 m	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
14.	<b>Captive water storage for fire fighting.</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire Service Inlet</li> <li>Access to tank</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Overhead tank capacity</li> </ul>	-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	-NA-	-NA-	-NA-
16.	<b>Provision of Lifts.</b>	Required	3,000 ltr Provided	-NA-
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift car</li> <li>Fireman's switch</li> <li>Lift signage</li> </ul>	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>	-NA-	-NA-	-NA-

N/116



• Detector system panel	-NA-	-NA-	-NA-
• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-
20. <b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2019/SZ/1882 Dated 01/10/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

14/19/07/2022

Signature of the Inspecting Officer  
Name Sh Rajesh Kumar  
Design ADO (BCP)

Dy CFC (SZ)

F.F.

ADO (BCP)

As approved, F.F. letter is put up for your signature pl

14/19/2022

Dy CFC/SZ

M.S. CC