

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No F 6/DFS/MS/School/2022/SZ/ 823

Dated: 29/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **Fr. Agnel School** at Gautam Nagar, New Delhi 110049 comprised of basement, ground plus three upper floors owned/occupied by Fr. Agnel School was issued Fire Safety Certificate by this department vide letter no. F6/MS/DFS/School/2019/SZ/2042 Dated 23-10-2019. The premises was re-inspected by officer concerned by this department on 14/07/2022 in the presence of Mr. Robert (caretaker) of the school and observed that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from 29/7/2022 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 29/7/2022 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Fr. Agnel School at Gautam Nagar, New Delhi 110049
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

M/13



INSPECTION REPORT

1	Name & Address of the Building	Fr Agnel School at Gautam Nagar, New Delhi-110049		
2	Type of Occupancy	Educational, Group- B (School)		
3	Building Comprised of	Two Blocks - Basement, Ground + 03 upper floors & One Block - Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2019/SZ/2042 Dated 23-10-2019		
6	Fire Safety Directives Letter No	DOE circular no 262 to 362 dated 17/01/2005		
7	Date of Inspection	14-07-2022		
8	Name of the Inspecting Officers	Sh Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr Robert (Caretaker)		
10	Year of construction	1986		
11	Applicant letter No	FASD/SO/ADM-II/716 dated 22-06-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Accessible	09 mtr	MR
	• Gate width	NA	5 mtr two nos	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 Nos in each	Provided	MR
	➤ Basement floor	02 Nos in each	One block-01 no & other blocks - 02 nos	MR (old case)
	b) Width of Staircase			
	➤ Upper floors	Required	Blk 1- 1.50 m each Blk 2 - 1.50 m each Blk 3 - 1.50 m & 0.70m	MR (old Case)
	➤ Basement floor	Required	Blk- 1 - 1.50 m other Blk 83cm&1.45 m ramp	MR (old case)
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 Nos each block having ground plus one upper floor	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	50 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			

N/A

N/A


	<ul style="list-style-type: none"> Total numbers on each floor Length of hose-reel hose Nozzle Diameter 	05 No's at each	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	-NA-	Provided	-NA-
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box 	100mm	Provided	MR
		05 Nos at each	Provided	MR
		05 Nos at each	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey Pump output Jockey Pump head Standby Pump output Standby Pump head Auto Starting/Manual Stopping Pump house access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of pump Power supply Auto starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450 & 180 LPM	900 & 900 LPM	MR
		40m each	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire Service Inlet Access to tank Overhead tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		5,000 Ltr	15,000 Ltr (02 blks)	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Fireman's switch Lift signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-

MR
MR
MR

-NA-
-NA-
-NA-
-N
-7

N/15



	• Location			
19.	Fire Control Room.	-NA-	-NA-	-NA-
	• Detector system panel	-NA-	-NA-	-NA-
	• Flow switch panel	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			
The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection				
Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/MS/DFS/School/2019/SZ/2042 Dated 23-10-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended				
Accordingly DFA is put up for approval and signature please.				
		 Signature of the Inspecting Officer Name Sh. Rajesh Kumar Design ADO (BCP)		

Dy. CFO (SZ)

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl.

1/4
2012

Dy CFO (SZ)

M.S. all