



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-31

75
भारत सरकार
नए दिल्ली-110001


No. F6/DFS/MS/School/WZ/2022/ 816

Dated 29/7/2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Kanya Vidyalaya (ID-1617014)**, Located at **Mundka, Delhi-110041**, comprised of **03 Blocks, Old building=Ground + 02 Upper floors, One M. P. Hall & New Building, Block-A& B=Ground + 03 Upper Floors** was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2018/WZ/34 dated 03.01.2018** owned/occupied by **Govt. Sarvodaya Kanya Vidyalaya (ID-1617014)** have complied with the fire prevention and fire safety requirements in accordance D.O.E Cr. No. 3298 to 3398 dated 01.03.2011 and Verified by the officer concerned of Fire Service on 19.07.2022 in the presence of Sh. Rajbir Malik (Estate Manager) and that the premises/building is fit for occupancy class "Educational" Group B with effect from 29/7/2022 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 29/7/2022 at New Delhi by


(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education Old Secretariat, Delhi – 110054.
2. The Principal, Govt. Sarvodaya Vidyalaya (ID-1617014), Mundka, Delhi-110041.

Following fire safety directive must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: - **Govt. Sarvodaya Kanya Vidyalaya (ID-1617041)**
Located at **Mundka, New Delhi-110041.**
2. Type of Occupancy: Educational, 03 blocks (Old Building=Ground + 02 Upper floors, Two New Block, BL-A & B=Ground + 03 Upper floors & **one M.P. Hall**)
3. Type of Case : Renewal/addition (Old block & M.P. Hall)
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/34 dated 03.01.2018
5. Fire Safety directives Letter No. : Cr. No.3298-3398 dated 01-03-2011/NBC Part-VI
6. Date of inspection : 19.07.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Rajbir Malik (Estate Manager)
9. Year of Construction : Before 2011 (Old building) & 2017 (New building)
10. Applicant's letter No. : email dated 17.05.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/as per FSC dated 03.01.2018		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 m	Provided		MR
	• Gate width	4.5 m	Direct accessible form road		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	02 nos. each block	Provided		MR
	• Basements	NA	NA		NA
	b. Width of staircases				
	• Upper floors	1.5 m each block	Old Block- 1.7 m & 1.68 m New Block A & B- 1.8 m x 2		MR
	• Basements	NA	NA		NA
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	01	Provided		MR
	e. Width Of Corridor	1.5 m	Provided		MR
	f. Door Size	1 m	Provided		MR
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	12 a/c per hours	Natural Ventilation		MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	32 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 nos. each block 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 lpm each block 30 m Required Required	NA NA NA NA NA NA NA NA NA NA Provided NA Provided Provided	NA NA NA NA NA NA NA NA NA NA MR NA MR MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA NA NA NA 10,000 ltrs. each block	NA NA NA NA Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA


2-21

17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcomings issued vide letter no. F6/DFS/MS/School/WZ/2021/14 dated 05.01 2021 are rectified.

Note: - M P Hall with area 476 sq. meters is having 02 doors of width 1.90 m & 03 doors of 1.5 m having no fixed sitting arrangements. Hall is protected by hose reel on both side and fire extinguisher.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, grant of Fire Safety Certificate is recommended.


 Aman Kumar Lathar
 ADO (JWP)

~~DO (W)~~

~~DO (W)~~

DO (W) ~~2021/2022~~
 DATED 20/7/2022


~~DO (W)~~

DO (W) ~~25/7/2022~~

Director ~~24/07/22~~

Any SWP Sir, F.T. letter is put-up for your signature pl.

Director ~~29/7/22~~


 Aman Kumar Lathar
 ADO (JWP)