

C-22



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 819

Dated: 29/7/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **M. C. D. Primary Co-ed Model School, Sector-15-C, Rohini-89**, comprised of **3 Blocks, 01-Block-Gr. floor & 02 Blocks-Gr.+ 01 upper floors** owned/ occupied by **M. C. D. Primary Co-ed Model School** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the **Director of Education letter no 3298-3398 dated 01.03.2011** and verified by the officer concerned of Fire Service on **16.07.2022** in the presence of **Mrs. Bhavna Saxena (In-charge)** and that the building/ premise is fit for occupancy **Group B Educational** with effect from 29/7/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 29/7/2022 at New Delhi by

  
(~~Atty-Genl~~)  
**DIRECTOR**  
Ph; 011-23414000

OK  
29/7

**Copy to:**

1. The Principal, M. C. D. Primary Co-ed Model School, Sector-15-C, Rohini-89.
2. The Commissioner, NDMC, Sector-5, Rohini, New Delhi-110085.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms/)

10/2/21

2/11

1/11

1/11

1/11

1/11

**INSPECTION REPORT**

1. Name & address of the building : M. C. D. Primary Co-ed Model School, Sector-15-C, Rohini-89.  
 2. Type of Occupancy : Educational  
 3. Type of Case : New Case (3 Blocks, 01Blk-Gr. floor & 02Blk-Gr.+ 01 upper floor)  
 4. Details of Previous NOC : NA  
 5. Fire Safety directives letter No : Director of Education Circular Dated 01.03.2011.  
 6. Date of inspection : 16.07.2022  
 7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)  
 8. Name and designation of officers  
 From the building side : Mrs. Bhavna Saxena (In-charge)  
 9. Year of Construction : 1998 & 2002  
 10. Applicant's letter No. : OD No.28.02.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular Dated 01.03.2011	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m & 1.45m	MR
	• Width of internal road	NA	NA	NA
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	2.3m & 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.2m	MR
<b>3.</b>	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
<b>4.</b>	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
<b>5.</b>	<b>Fire Extinguishers</b>			
	• Total numbers	08nos.	08nos.	MR
	• Types	ABC/CO2	ABC-8	MR
	• IS marking	ISI marked	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

N/13

Special  
Protec

	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

22/19

Special Fire Protection System for Protection of special Risks, if any:

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010

*Ajay Kumar Sharma*  
21/7/22

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

~~DO (NW)~~

*[Signature]*  
19/07/2022  
By cfo (w2)

*[Signature]*  
25/7/2022

cfo *[Signature]*  
25/7/2022

Director *[Signature]*  
26/07/22

Ajay Kumar

FT letter is put up for kind perusal and signature please.

*Ajay Kumar*  
26/7/22

Director *[Signature]*  
26/07/22  
*om*