

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2022/ 836

Dated: 21/8/2022

FIRE SAFETY CERTIFICATE

Certified that the building of J M International School, Sector - 6, Dwarka, New Delhi - 110075 comprised of Basement, Ground +3 Upper Floors was issued FSC vide Letter No: F6/DFS/MS/School/2019/SZ/1136 Dated-28/05/2019. The premises was re inspected by the officer concerned of this department on 19/07/2022 in the presence of Sh. R.B Gupta (President) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service and that the premises is fit for occupancy class "Educational" Group B with effect from 21/8/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/8/22 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: 1. Sh. R.B Gupta (President) J M International School, Sector - 6, Dwarka, New Delhi.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/20
INSPECTION REPORT

1. Name & address of the building: J. M. International School, Sector – 6, Dwarka, New Delhi - 110075
2. Type of Occupancy : Educational (B+G + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/1136 Dated- 28/05/2019
5. Fire Safety directives Letter No. : Old case / As per NBC Part IV
6. Date of inspection : 19-07-2022
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. R.B Gupta (President)
9. Year of Construction : 2005, 2015
10. Applicant's letter No. : Email Dated 13/07/2022

Total Area = 4411sqm.
Covered Area = 688.22sqm
Class rooms = 39
No. of students = 1450

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	30 mtrs	MR
	• Gate width	5mtrs	5.5mtrs	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	03 Nos.	MR
	• Basements	02 Nos.	02 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 m	2X 92cm & 175cm	MR(Being old case)
	• Basements			
	c. Protection of exits	1.5 m	1.75 m & 1.5 m	MR
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	• Required	Required	01	MR
	e. Width Of Corridor			
	• 1.5 m	1.5 m	Provided	MR
	f. Door Size			
	• 1 m	1 m	1.10 m	MR



N/91				
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per charge	Exhaust fans	MR
	• Upper floors	12 a/c per charge	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	01 no.ABC & CO ₂ for every 300 sq m	18 Nos.	MR
	• Types	ISI marked	Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2X450lpm	900 lpm, 180 lpm	MR being old case
		30 m	30 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 ltr	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA

			11/23	
20.	Special Fire Protection Systems for Protection of special Risks, if any:	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2019/SZ/1136 Dated-28/05/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

19/10/2019/12

Signature of the Inspecting Officer

Name *Uday Vir Singh*

Designation *ADDO/MS*

19/10/2019/12

ADDO (S)

[Signature]

FT,

ADDO (S)

5th FT letter is put for his file

Dyeroluz

[Signature]

M.S. [Signature]

19/10/2019/12