

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2022/ 218

Dated: 2 /08/2022

FIRE SAFETY CERTIFICATE

Certified that the **The Yellow Chilli Restaurant** running at **GF, C-57, Preet Vihar, New Delhi-92** comprises of **Basement + Ground + 03 Upper floors**, owned/occupied by M/s Royal Hospitality, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on **19/07/2022** in the presence of Mr. Sachin Jain and found that the building/premises is fit for occupancy class "**Assembly**" (**Group D**)/ **Eating House, (Restaurant running on Ground floor only)** with effect from ~~2/8/22~~ for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued ~~24-8-22~~ at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

1. The Joint Commissioner of Police,
1st floor, Police Station, Defence Colony, New Delhi – 110024.
Online application ID no. 2022070113832.
2. The Manager,
The Yellow Chilli Restaurant,
GF, C-57, Preet Vihar, Delhi-92.
3. The Dy. Health Officer,
MCD Health Departement, Shahadra (South Zon), Karkardooma, Shahadara, Delhi.

Condition for the validity of fire safety certificate

- 1) All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2) Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5) This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6) The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7) The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8) The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9) Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

- | | |
|---|---|
| 1. Name & address of the building | The Yellow Chilli Restaurant
GF, C-57, Preet Vihar, Delhi-92 |
| 2. Type of occupancy:- | Assembly Building Group-D
B + Ground + 03 Upper floor
Restaurant running on Gr. floor only |
| 3. Type of case:- | New Case |
| 4. Details of previous FSC:- | N/A |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 19/07/2022 |
| 7. Name of the inspecting officer:- | Sh. A.K Jaiswal (DO/ED) &
Sh. Manoj Kumar Sharma (ADO/LN) |
| 8. Name & designation of officer from the building side:- | Mr. Sachin Jain |
| 9. Year of construction:- | 2006 |
| 10. Applicant's letter No:- | ID no. 2022070113832 dated 05/07/2022 |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr	36 & 13.8 mtr.	MR
	2) Gate width	On main road	On main road	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 x 1.5 mtr.	2 x 1.5 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A

8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	10) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	11) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A

W

	c) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Mush
25/7/22

Signature of the Inspecting Officer
Name :- M.K. Sharma
Designation :- ADO (LN)

A.K. Jaiswal
25/07/2022

Signature of the Inspecting Officer
Name :- A.K Jaiswal
Designation :- DO (ED)

~~Dy. CFO (NDZ)~~

What is the use of upper floors?

Living
26/07

~~DO (ED)~~

offices & grooming classes.

~~Dy. CFO (NDZ)~~

A.K. Jaiswal
28/07/22

~~C.F.O.~~

Mush
28/7/2022

~~Director (M)~~
29/07/22

ADO LN

A.T. letter is put up for sig. of

~~Dir. Ops~~
Mush
11/8/22

uploaded
02/8/22

Mush
01/8