

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2022/SZ/ 821

Dated: 29/07/2022

FIRE SAFETY CERTIFICATE

Certified that **Mata Gujri Public School**, at Gurdwara Singh Sabha (opp. C Block), Greater Kailash -I, New Delhi-110048 comprised of 03 Blocks, Block 01- G+3, Block 02- G+1, Block 03- B+G+2 upper floors owned/occupied by Mata Gujri Public School, was issued Fire Safety Certificate by this department vide letter no. F6/MS/DFS/School/2019/SZ/1445 Dated 16-07-2019. The premises was re-inspected by officer concerned by this department on 14/07/2022 in the presence of Mrs. Daljeet Kaur Bhandari of the school and observed that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no 262-362 dated 17/01/2005 and that the building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from 29/7/2022 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 29/7/2022 at New Delhi by

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Mata Gujri Public School, Gurdwara Singh Sabha (opp. C Block, Greater Kailash - I, New Delhi-110048
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate: -


1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

M/2

INSPECTION REPORT

1	Name & Address of the Building	Mata Gujri Public School, Gurdwara Singh Sabha (opp. C Block, Greater Kailash -I, New Delhi-110048		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Three Blocks :- 1 st Block- Ground + Three Upper floor, 2 nd Block- Ground plus First floor, 3 rd Block- Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2019/SZ/1445 Dated 16-07-2019		
6	Fire Safety Directives Letter No	DOE circular no 262 to 362 dated 17/01/2005		
7	Date of Inspection	14-07-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Daljeet Kaur Bhandari		
10	Year of construction	2007		
11	Applicant letter No.	MGPS dated 05-07-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible NA NA	06 mtr 4.5 mtr NA	MR NA NA
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	02 No's 02 No's	Blk-1- Ground to terrace 02 No, ground to 2 nd -01 ground to 3 rd -01 no Blk-2-02 No's Blk -3-02 No's	MR MR
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	1.50m/0.75m 1.50m/0.75m	Blk-1- Ground to terrace- 1.30 & 1.1.m ground to 2 nd -3.40m, ground to 3 rd -1.39m Blk-2-1.40m each Blk -3-1.50 m each	MR (old Case) MR (old case)
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d) No. of continuous staircase to terrace	Blk- 02 No Blk- 01 No Blk- 01 No	Blk- 02 No Blk- 01 No Blk- 01 No	MR MR MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH 12 ACPH	Exhaust fan provided -NA-	MR -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required ABC / CO2 ISI marked	36 Nos ABC & CO2 Provided	MR MR MR
6.	First Aid Hose Reels.			

114

20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-
<p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.</p>		
<p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2019/SZ/1445 Dated 16-07-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p>		
<p>Accordingly DFA is put up for approval and signature please.</p>		
		<p style="text-align: right;">  Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP) </p>

Dy. CFO (SZ)

F.T.



~~ADO (B) (P)~~

As approved, F.T. letter is put up for your signature pl

11/6
28/7/22

Dy CFO (SZ)



M.S. 44