

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**

No.F6/DFS/MS/School/2022/SZ/ 848

Dated: 03/08/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **New Holy Public School, Shish Ram Park, Bindapur Road, Uttam Nagar, New Delhi-59**, comprised of ground plus four upper floors, owned/occupied by New Holy Public School was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/2010/2549 Dated 01/09/2010**. The school building was re-inspected by the officer concerned of this department on dated 22/07/2022 in the presence of **Sh. Ajay Arora (Chairman)** and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 35 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....03/08/2022..... at New Delhi.



(Sunil Chawdhary)

**Dy. Chief Fire Officer**  
Delhi Fire Service



Copy to:-

1. The Principal,  
New Holy Public School, Shish Ram Park, Bindapur Road, Uttam Nagar, New Delhi-59.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/C

- Name & address of the building : New Holy Public School, Shish Ram Park, Bindapur Road, Uttam Nagar, New Delhi-59.
2. Building is comprised of : G+4 upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/2010/2549 Dated 01/09/2010
6. Fire Safety direction letter No : DFS Act & Rules 2010
7. Date of Inspection : 22/07/2022
8. Name of the Inspecting officers : ADO R.K. Yadav & DO Vedpal Chhikara
9. Name and designation of Officer:  
From the building side : Sh. Ajay Arora (Chairman)
10. Year of Construction : Before 2010
11. Applicant's letter No. : NHPS/07/2022 dated 11/07/2022

S. N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 m. N/A N/A	Provided N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	03 Nos. N/A	03 Nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	1.50 m & Less than N/A	1.50, 1.25 & 1.20 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	02 No.	03 No.	MR
	e. Width of Corridor	1.5 m.	1.0 m.	MR old accepted
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A Required	N/A Natural Ventilation	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12 nos. ABC /CO <sub>2</sub> IS I marked	Provided ABC /CO <sub>2</sub> ISI marked	MR MR MR

1c

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 05mm	Provided Provided	MR MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 No.	Provided	MR
	• Hose Box	02 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM & 180 LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
➤ Power supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	25,000 Ltrs Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/2010/2549 Dated 01/09/2010 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

**Note:- The height of the building is measured by MCD (AE) & found 14.93 Meters certificate placed (C-13).**

Accordingly DFA is put up for approval please.

Signature of Inspecting Officer  
 Name:- R.K.Yadav  
 Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer  
 Name:- Vedpal Chhikara  
 Designation:- Divisional Officer

DCFO(South/Zone)

ADD R.K.Y.

R T letter is put up for sign. please

DYCP/CS

M.S. ul

Rec'd  
 2/8/2022