

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/EH/2022/NW2/215

Dated 01/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Mama's Buoi (A Unit of Ms Food Studio)** located at **FF & SF, 2624, Hudson Lane, Kingsway Camp, Delhi-110009** in the building comprised of ground and 03 upper Floors owned/ occupied by **M/s Mama's Buoi (A Unit of M/s Food Studio)** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2018/EH/WZ/1577 dated 06.07.2018** The premises was re-inspected by the officers concerned of this department on **21.07.2022** in the presence of **Sh. Saurabh Luthra** and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building/ premise is fit for occupancy **Class- "D" (Assembly) for first & second floor only** occupancy with effect from...**01/08/2022** for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **01/08/2022** at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph. No. 011-23414250

Copy to:-

1. The Manager, M/s Mama's Buoi (A Unit of Ms Food Studio) located at FF & SF, 2624, Hudson Lane, Kingsway Camp, Nagar, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. **This Fire Safety Certificate is valid only for restaurant at 1st & 2nd floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Mamas Buoit (A Unit of M/s Food Studio), 2624, First floor & Second Floor, Hudson Lane, Kingsway camp, Delhi.
2. Type of Occupancy : Assembly/ (Restaurant)
3. Composition of building : Ground & 03 upper floors only, ground & third floor other property
(Restaurant running at first floor & second floor only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2018/EH/WZ/1577 Dated: 06.07.2018
6. Fire Safety directives letter No : BBL
7. Date of inspection : 21.07.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Saurabh Luthra
10. Year of Construction : 2010
11. Applicant's letter No. : Online E-Mail I.D No.2022062113299 dated 22.06.2022

	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	06m	MR
	• Gate width	5m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.25m	01m & 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	01m	01m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	14nos ABC & Co2 Yes	15nos ABC-15 Yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30m 5mm	Provided 30m 5mm	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required NA NA NA NA	Provided NA NA NA NA	MR NA NA NA NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA Required NA	NA Provided NA	NA MR NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm 01 01	100mm 01 01	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA 1620LPM 40m NA Required	NA NA NA NA NA NA NA NA NA Provided 40m NA Provided	NA NA NA NA NA NA NA NA NA MR MR NA MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	NA NA NA	NA NA NA	NA NA NA

	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no.1577 dated 06.07.2018 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

~~DO (NW)~~
 By [Signature] 22/07/2022
 By [Signature] 1/8/22

[Signature]
 Signature of the Inspecting Officer
 Name: - C.L. Meena
 Designation:- ADO/RN

~~ADO/RN~~
[Signature] 21/7/22

As approved, F.T. Letter is put up for your signature pl.

~~ADO (NW)~~
[Signature] 1/8/22
 MS/CCY

[Signature]
 29/07/2022
 Uploaded
 08/08/22