

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/ 868

Dated:- 10/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Amity International School** located at **Mayur Vihar Phase-1, Delhi-91** comprised of **Basement + Ground + 04 Upper floors**, owned/occupied by Amity International School has already been issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/ 2019/438 dated 26/02/2019**. The premises was re-inspected by the officers concerned of this department on **30/07/2022** in the presence of the Mr. Sunil Pandit (Admin Officer) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with NBC Part-IV and premises is fit for occupancy of class "**Educational Building**" (**Group B**) with effect from ~~10/8/22~~ renewed for a period of three years, subject to conditions printed below.

Issued on10/08/2022..... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
ok
m

Copy to:-

1. The Director of Education,
Government of N.C.T. Delhi,
Old Sectt. Delhi – 110054.
2. The Principal,
Amity International School,
Mayur Vihar Phase-1, Delhi-91.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building Amity International School at Mayur Vihar Phase-1, Delhi-91
2. Type of occupancy:- Educational Group-B
B + Gr. + 04 Upper floors
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/2019/438 dated 26/02/2019
5. Fire safety directives No.- NBC Part-IV
6. Date of inspection:- 30/07/2022
7. Name of the inspecting officer:- Sh. A.K. Jaiswal (DO/ED) &
Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. Sunil Pandit (Admin Officer)
9. Year of construction:- 2005
10. Applicant's letter No:- AIS/MV/APP/FC/2022-03 dated 18/07/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	15 mtr. ✓	MR
	2) Gate width	06 mtr.	06 mtr. ✓	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 no.	03 nos. ✓	MR
	2. Basements	02 no.	02 nos. ✓	MR
	B. Width of staircase			
	1. Upper floors	1.5 m	1.5 mtr. each ✓	MR
	2. Basements	1.5 m	1.5 mtr. each ✓	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 nos.	02 nos. ✓	MR
	E. Width of corridor	1.5 mtr.	2.0 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Sealed ✓	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Exhaust fan	Provided	MR
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	25 Nos.	30 Nos. ✓	MR



	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked /	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	02 nos. /	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm /	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A /	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided /	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided /	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm /	MR
	2) Number of hydrants per floor	2 no.	2 no. /	MR
	3) Hose box	2 no.	2 no. /	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level		/	
	a) Discharge of pump	450 LPM	900 LPM /	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	1,00,000 ltrs. /	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

N/30 -

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	25,000 ltrs.	25,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

Note: Encroachment removed (photo enclosed at C/59 & C/60).

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/School/NDZ/2022/47 dated 03/02/2022 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/2019/438 dated 26/02/2019, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Murli
Signature of the Inspecting Officer
Name :- M.K. Sharma
Designation :- ADO (LN)

A.K. Jaiswal
Signature of the Inspecting Office
Name :- A.K. Jaiswal
Designation :- DO(ED)

Dy. C/O (NDZ)

What about the Temp. Structure constructed at 4th floor? If removed, enclose the photographs.

*Dir
02/08/22*

DO(ED)
A.K.
04/08/2022

ADO/LN

Temp structure found removed

note
A.K.
04/08/2022

Murli
4/8

RTO