

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

F6/DFS/MS/EH/NDZ/2022/

353

Dated:

08/08/2022

FIRE SAFETY CERTIFICATE

Certified that the "Eating House" in the name and style of **M/S Jamuna Lodge Masonic Centre** located at **1 C Alipur Road, Qudsia Garden, New Delhi- 110054** comprised of **ground floor only** owner/occupied by M/S Jamuna Lodge Masonic Centre was granted FSC by this department vide letter no. F6/DFS/MS/2017/WZ/1782 dated 11.12.2017. The premises was re-inspected by the officer concerned of this department on 23.07.2022 in presence of Mr. Padam Bisht and found that the premise/building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the building/premise is fit for occupancy Class D "**Assembly Building**" for **ground floor only** with effect from08/08/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on08/08/2022.....at New Delhi by

(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2022052110868 dated 24.05.2022.
2. The Licensee, M/S Jamuna Lodge Masonic Centre at 1 C Alipur Road, Qudsia Garden, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	M/s Jamuna Lodge Masonic Centre at 1 C Alipur Road, Qudsia Garden, New Delhi - 110054.
2.	Type of occupancy with details of floors:	Assembly Building Class-D (Restaurant) Ground floor only
3.	Type of case:	Renewal
4.	Details of previous FSC:	F6/DFS/MS/2017/WZ/1782 dated 11.12.2017
5.	Fire safety directives no.:	NA
6.	Date of inspection:	13.07.2022
7.	Name of the inspecting officer:	Mr. Sumit Kumar ADO (SPM)
8.	Name and designation of the officer from the building side:	Mr. Padam Bisht
9.	Year of construction:	Old
10.	Reference letter no.:	Online ID no. 2022052110868 dated 24.05.2022

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per NBC)	Provide at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	Required	Accessible (On road) MR
	B	Gate width	NA	NA
	C	Width of internal roads	NA	NA
2	Number, Width, Type & Arrangement of Exits:			
	A	No. of Staircase:		
		a) Upper floor	NA	NA
		b) Basements	NA	NA
	B	Width of the Staircase:		
		a) Upper floors	NA	NA
		b) Basements	NA	NA
	C	Protection of Exits		
		a) fire check door	NA	NA
		b) pressurization	NA	NA
	D	No. of continuous staircase to terrace	NA	NA
	E	Width of the corridor	1.5 meter	Provided MR
	F	Door size		
		a) Main exits	1.5 meter	Provided MR
		b) Alternate exist	1.5 meter	Provided MR
3	Compartmentation:			
	A	Fire check doors	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA
	C	Fire rating of shaft doors	NA	NA
	D	Water curtain	NA	NA
	E	Fire dampers	NA	NA
4	Smoke management System:			
	A	Basements	NA	NA
	B	Upper floors	NA	NA
5	Fire extinguishers:			
	A	Total numbers	04 no.	04 no. MR
	B	Types	ABC & CO ₂	ABC & CO ₂ MR
	C	ISI marking	ISI marked	ISI marked MR


6	First Aid Hose reel:				
	A	Total no. at each floor	01 no.	01 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Ground & upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of down comer	NA	NA	NA
	B	No. of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements:				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	450 LPM	MR
		b) Head of terrace pump	30m	30m	MR
		c) Alternate power supply	Required	Required	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	2,500 ltr.	2,500 ltr.	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of lift:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		Required	Provided	MR


11/11-

18	Refuge Areas:					
A	Location			NA	NA	NA
B	Total area			NA	NA	NA
19	Fire Control Room:					
A	Fire detection system panel			NA	NA	NA
B	Flow switch panel			NA	NA	NA
C	P a system panel			NA	NA	NA
D	Battery backup			NA	NA	NA
E	Building floor plan			NA	NA	NA
20	Special Fire Protection for special risk if any					
A	Special Fire Protection system for Protection of Special Risk, if any:					NA


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.


In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/2017/WZ/1782 dated 11.12.2017 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.



 Signature of the Inspecting Officer
 Name Sumit Kumar
 Designation ADO (SPM)


 DO (CD)
 29/7/22


kindly mention width of Exits.




 29/07/22


 D.O. (CD)
 29/7/22



 ADO (SPM)
 29/7/22

1. width of exits & corridor marked on the inspection note.
 Resubmitted, Please.


 03/08/2022



 D.O. (CD)
 29/7/22

 ADO (SPM)

F.T. please.


 03/08

ADO (SPM)

F.T. letter is Put up for Signature, Please.


 04/08/2022

971 ADO (SPM)