

C103

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/BNQT./2022/SZ/42

Dated: 5/8/22

FIRE SAFETY CERTIFICATE

Certified that the **M/s Golden Gate Banquet Hall** running at ground floor only in a building comprised of basement, ground plus one upper floor located at Plot No. B-18, Maya Puri, New Delhi, owned/ occupied by M/s Golden Gate Banquet Hall was issued FSC by this department vide letter no. F6/DFS/MS/BNQT./2019/SZ/2098 dated 31/10/2019. The building was re-inspected by the officers concerned of this department on 08/07/2022 in the presence of Sh. Rohit Kalra (Owner) and found that the banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor Only**) is fit for occupancy Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....5/8/22.....at New Delhi.


(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Executive Engineer (Building-I), S.D.M.C, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. The Manager, M/s Golden Gate Banquet Hall, Plot No. B-18, Maya Puri, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/23

INSPECTION REPORT

1. Name & address of the building :	M/s Golden Gate Banquet Hall, Plot No. B-18, Maya Puri, New Delhi
2. Building comprised of :	basement, ground plus one upper floor but banquet hall is on GF only.
3. Type of Occupancy :	Assembly D-3
4. Type of Case :	Renewal
5. Details of Previous NOC :	F6/DFS/MS/BNQT./2019/SZ/2098 dated 31/10/2019
6. Fire Safety directives letter No :	F.6/DFS/MS/BP/2019/2732 dated 08.05.2019
7. Date of inspection :	08/07/2022
8. Name of Inspecting Officer :	A.D.O. R.K.Yadav
9. Name and designation of officers From the building side :	Sh. Rohit Kalra (Owner)
10. Year of Construction :	Before 2010
11. Applicant's letter No. :	ID 2022050509480 dated 07/05/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL-16/NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (09 mtrs.) 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s 02 no.'s	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & 1.20 M 1.50 & 1.50M	1.50 & 1.20 M 1.50, 1.50 M & 01 ramp	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	2 M	Opening in hall	MR
	f. Door Size on Ground floor	2 M (03 no.'s)	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floor 	Required Required	Exhaust fans are provided Exhaust fans are provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers on each floor Types IS marking 	06 no.'s ABC/CO ₂ /W CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no. 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

N/24

7.	Automatic fire detection and alarming system			
	• Type of detectors Smoke/Heat	Required	Provided	MR
	• Location of Main Panel	Required	GF	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	In hall	MR
8.	MOEFA With talk back system	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	Required 100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	One	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Terrace level			
	➤ Pump House Access	N/A	N/A	N/A
	• Discharge of pump	900 LPM	Provided	MR
	• Head of the pump	40 mtrs	Provided	MR
	• Power Supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

Fire Control Room

• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/BNQT./2019/SZ/2098 dated 31/10/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per the undertaking given by the proprietor (Mr. Rohit) Building is comprised of Basement (intended to use as car parking), ground plus one upper floor but banquet hall is running at Ground floor only and first floor not in use for banquet purpose having semi pucca roof was found vacant at the time of inspection.

R K Yadav
19/7/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

DO (South West) *What is the occupancy at others floors.*

ADD (ANKPURI)

MS
15/7/22

*Basement is used for car parking, 1st floor is vacant, & Banquet Hall is running at Ground floor only.
Submitted please*

DO(SW) 19/7/22

F.F. MS 18/7/2022

DO(SW)

[Signature]

ADD (ANKPURI)