



No. F6/DFS/MS/Hospital/WZ/2022

1348

Dated: 04/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Jivodaya Hospital** Located at, **Ashok Vihar, Phase-1, Delhi-110052** comprised of Basement + Ground + 03 Upper Floors was issued Fire Safety Certificate vide Letter No. **F6/DFS/MS/WZ/Hospital/2019/528 dated 14.03.2019**. The said premises was re-inspected by the officer concerned of this department on 29.06.2022 in the presence of Ms. Deepthy SD and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010, and that the premises/building is fit for occupancy class "Institutional Building" Group C Sub Division C-1 with effect from 04/08/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ...04/08/2022 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. Ms. Deepthy SD (Administrator), Jivodaya Hospital, Ashok Vihar, Phase-1, Delhi-110052.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolt /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of building Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building: **Jivodaya Hospital** Located at **Ashok Vihar, Phase-I, Delhi-110052**
2. Type of Occupancy : Institutional (Basement + Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/Hospital/2019/528 dated 14.03.2019
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 29.06.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Ms. Deepthy SD
9. Year of Construction : 1996
10. Applicant's letter No. : email Dated 20.06.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements/ as per FSC dated 14.03.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	16 m	9 m	MR(Old Case)
	• Gate width	4.5 m	430 cm	MR(Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper floors	1.35 m x 1	Provided	MR
	• Basements	Required	120 cm x 1 & 135 cm x 1	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	240 cm	MR
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	10 a/c per hr	Provided	MR
	• Upper floors	12 a/c per hr	Open able window	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	DCP & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants:			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements: All the pumps are electrical pump & Connected to electrical generator			
	• Ground Level	1620 lpm	Provided	MR
	• Discharge of main pump	40 m	Provided	MR
	➤ Head of main pump	1	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	40 m	Provided	MR
	➤ Jockey pump head	1620 lpm	Provided	MR
	➤ Standby Pump out put	40 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	• Under ground tank capacity	75,000 litrs	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Accessible	Provided	MR
	• Overhead Tank capacity	10000 litrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were checked and found functional at the time of inspection. The Shortcoming issued vide letter no. F6/DFS/MS/Hospital/2022/WZ/953 dated 29.04.2022 are rectified.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/Hospital/2019/528 dated 14.03.2019 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

Gurpreet Singh
27/07/22
Aman Kumar Lathar
ADO (JWP)

D.O. (WEST) 371
DATED. 27/07/2022

DO (W)

27/07/2022

DO (W)

27/07/22

ADO (JWP)

F.S. letter is put-up for signature M.

DO (W)

27/07/22

MS/AD

Gurpreet Singh
03/08/22
ADO (JWP)