

996

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/BNQT/SZ/2022/41

Dated: 02/8/2022

FIRE SAFETY CERTIFICATE

Certified that M/s. **The Gracious Banquet (A unit of Grace)** located at **A-25, Naraina Industrial Area, Phase- II, New Delhi- 110028**, was granted FSC vide this department letter No. F.6/DFS/MS/BNQT/2019/SZ/1619 dated 13.08.2019, comprised of ground floor, first floor, small mezzanine floor (used as office) and second floor. The banquet hall was re-inspected by the officers concerned of this department on 19.07.2022 in presence of Sh. Sahib (manager) and found that M/s The Gracious Banquet (A unit of Grace) have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D 'Assembly Building', **(for Ground floor, First floor, Small Mezzanine floor for office use and second floor only)** with effect from 02/8/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 02/8/2022 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Online application Id no. 2022052110882 dated 26.05.2022

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. If the owner/occupier open the wall connected with A-21/17, the FSC will be automatically null & void.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

N/9

INSPECTION REPORT

1. Name & address of the building : M/s. The Gracious Banquet (A unit of Grace), A-25, Naraina Industrial Area, Phase- II, New Delhi- 28.
2. Type of Occupancy : Assembly
3. Building Composition : The said Banquet comprised of ground floor, first floor, small Mezzanine floor (used as office) and second floor.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/BNQT/2019/SZ/1619 dated 13.08.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 19.07.2022
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
9. Name and designation of officers from the building side : Sh. Sahib, Manager
9. Year of Construction : 2005-06
10. Applicant's letter No. : Online Application Id 2022052110882 dated 26.05.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 13.08.2019	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 Mtrs N/A N/A	Provided Directly accessible N/A	MR N/A N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 N/A	02 N/A	MR N/A
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2.0 mts each N/A	2.0 mts each N/A	MR N/A
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	2.0 mts.	Opening in hall	MR
	h. Door Size	2.0 mts.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A Natural Ventilation & Exhaust fan provided	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	16 CO ₂ , ABC, WCO ₂ ISI marked	Provided Provided Provided	MR MR MR

N/10

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required N/A	provided Provided at ground floor N/A Provided Hall	MR MR N/A MR N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 02 02	Provided 02 02	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	01 01	N/A N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put (Electrical with D.G set back up) Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	<p>----</p> 2280 LPM 55 mts 01 180 LPM 55 mts 2280 LPM 55 mts Required Required <p>-----</p> 450 LPM 30 mts Required Required	<p>----</p> Provided Provided 01 180 LPM 55 mts Provided Provided Provided Provided <p>-----</p> Provided Provided Provided Provided	<p>----</p> MR MR MR MR MR MR MR MR MR MR <p>-----</p> MR MR MR MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 lts N/A Required N/A 5,000 lts	50,000 lts N/A Provided N/A 10,000 lts	MR N/A MR N/A MR
15	Exit Signage.	Required	Provided	

M/11

Provision of Lifts.

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	CO ₂ /DCP	Provided	MR

The fire protection systems provided in the building were checked at random and found satisfactory at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No.F.6/DFS/MS/BNQT/2019/SZ/1619 dated 13.08.2019, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for signature please.

[Handwritten Signature]
20/7/22

Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)

[Handwritten Signature] 20/7/22

Signature of the Inspecting Officer
Name- P.V. Rathee Divisional
Asstt. Div. Officer (S.Rd)

[Handwritten Signature] F.T.
[Handwritten Signature]

A.O. (PA)
~~FT letter is put up for signature~~
[Handwritten Signature] 29/7/22

~~*[Handwritten Signature]*~~

P To