

c 20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F6/DFS/MS/2022 /School/ 876

Dated: 10/08/2022

FIRE SAFETY CERTIFICATE

Certified that the J.C. Gaur Public School located at **Ground Floor, Gali No.5 to 8, Som Bazar Road, Mukund Pur, Part-II, Delhi-110042** in a building comprised of 02 blocks interconnected (One old block G+02 upper floors & New Second block G+03 upper floors owned/ occupied by J.C. Gaur Public School was issued NOC vide this office letter no. **F-6/MS/DFS/2006/2359 dated 07.09.2006**. The premise was re-inspected by the officer concerned of this department on **29.07.2022** in the presence of **Sh. Rajesh Gaur** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B" for ground floor with five class rooms only** with effect from **10/08/2022** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **10/08/2022** at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi, Old Seett, Delhi - 110054.
2. The Principal, J.C. Gaur Public School located at Ground Floor Gali No.5 to 8, Som Bazar Road, Mukund Pur, Part-II, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. **This Fire Safety Certificate is valid only for ground floor with five class rooms for educational occupancy only. In case of any violation, this FSC will be treated as null & void.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBI.-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBI.-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building	J.C. Gaur Public School, Gali No 5 to 8, Som Bazar Road, Mukund Pur Part II, Delhi -110047
2. Composition of building	02 blocks interconnected (One old block G-02 upper floor & New Second block G-03 upper floor only) but school is running at ground floor only
3. Type of Occupancy	Educational
4. Type of Case	Renewal
5. Details of previous NOC	16 MS DIS 2006 2359 dated 07/09/2006 (Ground Floor only)
6. Fire Safety directives letter No	Director of Education Circular dated 17/01/2005
7. Date of inspection	29/07/2022
8. Name of the Inspecting Officers	ADO (RN)
9. Name and designation of officers from the building side	Sh. Rajesh Gaur
10. Year of Construction	2003, 2015 & 2020
11. Applicant's letter No	J.C.G.P.S.DIS/2022 dated 18/07/2022

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits	Ground floor only		
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor			
	f. Door Size	1m	85cm	MR (Old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a.c per hour	NA	NA
	• Upper floors	12 a.c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	03nos	04os	MR

		ABC CO2	ABC 04	MR
	<ul style="list-style-type: none"> Types ISI marking 			MR
6	First-Aid Hose Reels.	ISI Marked	Yes	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank 	NA	NA	NA

Op

	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

Note:-

The school management has given an undertaking to us in which they will only use the ground floor and no one else will use it. (see at c-16)

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 17.01.2005 the NOC issued vide letter of even no. 2359 dated 07.09.2006 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

DO (WZ)

[Signature]
03/02/2022

Dy CPO (WZ)

[Signature]
4/1/22

ADO/R.N

As approved, F.i. letter is put up for your signature pl.

Dy CPO (WZ)

[Signature]
4/1/22

[Signature]

[Signature]
Signature of the Inspecting Officer
Name :- C.I. Meena
Designation :- ADO/RN

[Signature]
05/08/2022