

2-40
9
c/50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/2022/WZ/School/ 827

Dated: 01/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85**, comprised of **Basement + Ground + 02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/2638 dated 07.12.2018**. The premises was re-inspected by the officer concerned of this department on **15.07.2022** in the presence of **Smt. Anjana Gupta (Headmistress)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy '**Group-B Educational**' with effect from 01/08/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/08/2022 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

etc
out

Copy to :-

1. The Principal, Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85.
2. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/)
[s/ http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

INSPECTION REPORT

1. Name & address of the building : Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Basement + Ground + 02 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2018/2638 dated 07.12.2018
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 15.07.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Smt. Anjana Gupta (Headmistress)
9. Year of Construction : 2002 & 2014
10. Applicant's letter No. : Online e-mail dated 08.07.2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5m NA	Accessible 4.0m NA	MR MR(Old Case) NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 02	02 02	MR MR
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m 1.5m	1.5m & 1.15m 1.5m & 1.15m	MR MR
	f. Protection of exits			
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan Natural ventilated	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08nos. ABC/CO2 ISI marked	09nos. ABC-09 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30mm 5m	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	NA NA NA NA	NA NA NA NA	NA NA NA NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm & 180lpm	450lpm & 180lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

N/25

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 39 dated 01.02.2022, the FSC issued vide letter no. F.6/DFS/MS/2018/2638 dated 07.12.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

[Signature]
19/07/22

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

[Signature]
19/07/2022

Dy CPO (W2)

[Signature]
25/7/22

AD - Rohini

FT letter is put up for kind perusal and signature please.

[Signature]
26/7/22

[Signature]
29/7/22

MS/CCP