



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

431
7
संज्ञा
संज्ञा

No.F.6/DFS/MS/School/2022/NDZ/ 866

Dated: 08 / 08 / 2022

FIRE SAFETY CERTIFICATE

Certified that the St. Lawrence Public Sr. Sec. School located at A-K Facility Center, Opp.-LIC Colony, Dilshad Garden, Delhi-110095, building comprised of Basement, Ground, First floor & Temporary rooms on Terrace (Second Floor) but school is running on Basement, Ground and First Floor only, owned / occupied by St. Lawrence Public Sr. Sec. School, was issued FSC vide letter No. F6/DFS/MS/School/2018/1119 Dated 17/05/18. The School building was re-inspected by the officer concerned of this department on 03/08/2022 in presence of Mrs. Shelly Sehgal and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E. Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) with effect from 08 / 08 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 08/8/2022 **at New Delhi by.**

(S.K. DUA)

DY. CHIEF FIRE OFFICER.

Copy to :-

1. The Principal, St. Lawrence Public Sr. Sec. School, A-K Facility Center, Opp.-LIC Colony, Dilshad Garden, Delhi-110095.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. Basement shall be used strictly as per Building By-Laws.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

H/113

1. Name & address of the building: St. Lawrence Public Sr.Sec. School,
A-K Facility Center, Opp.-LIC Colony, Dilshad Garden,
Delhi-110095.
2. Building is comprised of : Basement, Ground, First floor & Temporary rooms on
Terrace (Second Floor).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2018/1119 Dt. 17/05/2018
6. Fire Safety directives Letter No.: D.O.E. Circular No. 262-362 Dated 17/01/2005
7. Date of inspection : 03/08/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer
from the building side : Mrs. Shelly Sehgal
10. Year of Construction : 2006
11. Applicant's letter No. : E-Mail dt. 29/07/2022

| S. No | Minimum Standards on fire prevention and fire safety U/R 33 | Circular Requirement | Provided at Site | Remarks |
|-------|---|----------------------|-------------------|---------|
| 1 | Access to building | | | |
| | • Road width | 6.0 M | 7.0 M ✓ | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor | 02 Nos. | 02 Nos. ✓ | MR |
| | • Basement | N/A | N/A | N/A |
| | b. Width of Staircases | | | |
| | • Upper Floor | 1.50 M | 1.68 M & 1.53 M ✓ | MR |
| | • Basement | 1.50 M | 1.68 M & 1.53 M ✓ | MR |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | 01 Nos. | 01 Nos. ✓ | MR |
| | e. Width of Corridor | 1.50 M | 1.73 M ✓ | MR |
| | f. Door size | 1.0 M | 1.10 M ✓ | MR |
| 3 | Compartmentation | | | |
| | • Fire check Door | N/A | N/A | N/A |
| | • Sealing of electrical Shafts | N/A | N/A | N/A |
| | • Fire rating of Shaft Door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | • Total Numbers | 10 Nos. | 10 Nos. ✓ | MR |
| | • Types | ABC & Co2 | ABC & Co2 | MR |
| | • IS Marking | ISI Marked | ISI Marked | MR |

D/S

N/14

| | | | |
|--|-------------|-------------|-----|
| First-aid-Hose Reels | | | |
| Total numbers of each floor | 01 Nos. | 01 Nos. | MR |
| • Length of hose reel hose | 30 M | 30 M | MR |
| • Nozzle diameter | 05 mm | 05 mm | MR |
| Automatic fire detection and alarming system | | | |
| • Type of detectors | N/A | N/A | N/A |
| • Location of main panel | N/A | N/A | N/A |
| • Location of repeater panel | N/A | N/A | N/A |
| • Alternate source of power | N/A | N/A | N/A |
| 8 MOEFA | N/A | N/A | N/A |
| 9 Public address System | N/A | N/A | N/A |
| 10 Automatic Sprinkler System | | | |
| • Basement | Required | Provided | MR |
| • Upper Floor | N/A | N/A | N/A |
| • Sprinkler above false Ceiling | N/A | N/A | N/A |
| 11 Internal Hydrants | | | |
| • Size of rise/down-comer | N/A | 100 mm | N/A |
| • Number of Hydrants per Floor | N/A | 01 Nos. | N/A |
| • Hose Box | N/A | 01 Nos. | N/A |
| 12 Yard Hydrants | | | |
| • Total number of Hydrants | N/A | N/A | N/A |
| • Hose Box | N/A | N/A | N/A |
| 13 | | | |
| • Ground Level | | | |
| ➤ Discharge of main Pump | N/A | N/A | N/A |
| ➤ Head of Main Pump | N/A | N/A | N/A |
| ➤ Number of main Pumps | N/A | N/A | N/A |
| ➤ Jockey pump output | 180 LPM | 180 LPM | MR |
| ➤ Jockey pump head | 40 MH | 40 MH | MR |
| ➤ Standby pump output | N/A | N/A | N/A |
| ➤ Standby pump head | N/A | N/A | N/A |
| ➤ Auto starting/Manual stopping | Required | Provided | MR |
| ➤ Pump house access | N/A | N/A | N/A |
| • Terrace Level | | | |
| ➤ Discharge of pump | 450 LPM | 450 LPM | MR |
| ➤ head of the pump | 40 MH | 40 MH | MR |
| ➤ Power supply | Required | Provided | MR |
| ➤ Auto Starting of pump | Required | Provided | MR |
| 14 Captive Water Storage for Fire Fighting | | | |
| • Underground tank capacity | N/A | N/A | N/A |
| ➤ Draw-off connection | N/A | N/A | N/A |
| ➤ Fire service inlet | N/A | N/A | N/A |
| ➤ Access to tank | N/A | N/A | N/A |
| • overhead Tank capacity | 5,000 Ltrs. | 5,000 Ltrs. | MR |
| 15 Exit Signage | | | |
| | Required | Provided | MR |

[Handwritten signature]

| | | | | |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

Note:- Building comprised of Basement, Ground, First floor & Temporary rooms on Terrace (Second Floor) but Management has given an undertaking placed at C-27 that they will not use second floor for school purpose in any case. FSC is recommended for Basement, Ground & First Floor only.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/1119 Dated 17/05/18 has grant under circular No. 3298-3398 Dated 01/03/2011 is recommended.

Dy. CFO (AD2)

F.T. please.

[Signature]
04/08/22

[Signature]
03/08/2022

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

~~DO (E1)~~ Sir,

As Approved, F.T. is added for sign. AP

Dy. CFO (AD2)

[Signature]
08/08/22

[Signature]
05/08/2022

F.P. wing