

17-1  
E/E  
7/22  
452



454

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/ 226

Dated 08/8/2022

**FIRE SAFETY CERTIFICATE**

Certified that **3 Idiotss** located at **Shop No- HS1, First & Second Floor**, Kailash Colony Market, New Delhi 110048 in the building comprised of Basement Ground plus 02 upper floors owned/occupied by Unit of 3 Idiotss Bar Pvt Ltd. was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2019/SZ/1238 dated 11/06/2019. The restaurant premise was re-inspected by the officer concerned of this department on 04/08/2022 in the presence of Mr. Manoj Sharma and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 08/8/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/8/2022 at New Delhi by

**(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)**

Copy to :-

1. The Dy. Health Officer, Public Health Department, South Zone, Aurobindo Marg, Green Park, Delhi 110016 (Ref. MHA Portal 2022072815369 dated 28/07/2022)
2. **3 Idiotss** located at **Shop No- HS1, First & Second Floor**, Kailash Colony Market, New Delhi 110048

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. The basement shall be used as per the provisions of BBL /NBC Part- IV.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	M/s 3 Idiotss (A Unit of 3 Idiotss Bar Pvt Ltd, Shop No HSI, First & Second Floor, Kailash Colony Market, New Delhi 110048)		
2	Type of Occupancy	Group-D Assembly Building (Eating House)		
3	Building Comprised of	Basement, Ground plus two upper floors.		
4	Type of Case	Renewal Name change		
5	Details of Previous NOC	F 6/DFS/MSEH/2019/SZ/1238 dated 11/06/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	04/08/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr Manoj Sharma		
10	Year of construction	1992	<b>Restt. Running at FF &amp; SF only</b>	
11	Applicant letter No.	MHA Portal 2022072815369 dated 28/07/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC-2016	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 m N/A N/A	Provided N/A N/A	MR N/A N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	02	Provided	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25m/ 0.75m	1.50m & 0.85m	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	02 m & 1.0 m	2 m & 1.05 m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	NA 12 ACPH	N/A Exhaust Fans non functional	N/A NMR
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	10 Nos ABC/CO <sub>2</sub> ISI marked	12 Nos ABC-08 & CO <sub>2</sub> -04 Provided	MR MR MR
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	One 30m 5mm	Provided Provided Provided	MR MR MR

1/1/2

7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Ground/ upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box	One	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump output	N/A	N/A	N/A
	➤ Jockey Pump head	N/A	N/A	N/A
	➤ Standby Pump output	N/A	N/A	N/A
	➤ Standby Pump head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire Service Inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A

N/A



	• Location	N/A	N/A	N/A
19	<b>Fire Control Room.</b>			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	ABC type Fire Extinguishers provided near elec panel	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection. Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 497 dated 17/07/2022.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2019/SZ/1238 dated 11/06/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Designation: ADO (BCP)

Dy. CFO (SZ)

F.T.  
*[Signature]*

*[Handwritten initials]*

As approved, F.T. letter is forwarded for your signature P.I.

*[Signature]*  
 08/8/2022

*[Signature]*

*[Signature]*

M.S. Cell

uploaded

*[Signature]*  
 11/08/2022