

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2022/ 224

Dated: 05/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Hira Sweets and Restaurant** located at **E-60, Jawahar park, Laxmi Nagar, Delhi-110092** comprised of **Basement + Ground + 03 Upper floors, Basement (Storage), Ground floor (sweet shop), 1st floor (Restaurant), 2nd floor (Store/Office), 3rd floor (Office)** and **terrace tin shed. (Restaurant at first floor only)** owned/occupied by **Hira Sweets** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on **03/07/2022** in the presence of Mr. Rakesh Tiwari (GM) and found that the building/premises is fit for occupancy class "**Assembly**" (**Group D**)/ **Eating House**, with effect from 05/8/2022 for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 05/8/2022 at New Delhi by.


(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. The Deputy Commissioner (Licensing),
1st Floor, Police Station Defence Colony, New Delhi.
Online application ID no. 2022052010816.
2. The Manager,
Hira Sweets and Restaurant,
E-60, Jawahar park, Laxmi Nagar, Delhi-110092.

Condition for the validity of fire safety certificate

- 1 **Fire Safety Certificate is valid for first floor only.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 3 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 4 The trained fire fighting staff should be available round the clock.
- 5 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 6 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 7 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 8 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 9 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 10 Any flammable material for interior decoration is prohibited.

| INSPECTION REPORT | | | | |
|-------------------|---|---|------------------|----------------|
| 1 | Name & address of the building | Hira Sweets and Restaurant, E-60, Jawahar Park, Laxmi Nagar, Delhi-110092 | | |
| 2 | Type of Occupancy | Assembly Building (Restaurant) B + Gr. + 03 upper floors, Basement (Storage) Ground floor (Sweet shop), 1 st floor (Restaurant), 2 nd floor (Store/office), 3 rd floor (Office) and terrace tin shed. Restaurant running is 1 st floor only | | |
| 3 | Type of Case | New Case | | |
| 4 | Details of previous FSC | N/A | | |
| 5 | Fire Safety directives Letter No. | N/A | | |
| 6 | Date of inspection | 20.07.2022 | | |
| 7 | Name of the Inspecting Officer | Sh. A.K. Jaiswal (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN) | | |
| 8 | Name and Designation of Officer from the building side | Mr. Rakesh Tiwari (GM) | | |
| 9 | Year of Construction | 2008 | | |
| 10 | Applicant's letter No./ Online Id No. | 2022052010816 dated 30.05.2022 | | |
| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R 33 | Requirements | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building | | | |
| | 1 Road Width | 12 mtr. | 15 mtr. | MR |
| | 2 Gate Width | N/A | N/A | N/A |
| | 3 Width of Internal Road | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangements of exits | | | |
| | A Number of Staircase | | | |
| | 1 Upper Floors | 02 nos. | 02 nos. | MR |
| | 2 Basement | 02 nos. | 02 nos. | MR |
| | B Width of Staircase | | | |
| | 1 Upper Floors | 1.5 m each | 1.5 m each | MR |
| | 2 Basement | 1.5 m each | 1.5 m each | MR |
| | C Protection of Exits | | | |
| | 1 Fire Check door | N/A | N/A | N/A |
| | 2 Pressurization | N/A | N/A | N/A |
| | D No. of Continuous S/C to terrace | N/A | N/A | N/A |
| | E Width of Corridor | N/A | N/A | N/A |
| | F Door Size | 1.5 mtr. | 1.5 mtr | MR |
| 3 | Compartmentation | | | |
| | 1 Fire check door | N/A | N/A | N/A |
| | 2 Sealing of electrical shafts | N/A | N/A | N/A |
| | 3 Fire rating of shaft door | N/A | N/A | N/A |
| | 4 Water curtain | N/A | N/A | N/A |
| | 5 Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System | | | |
| | 1 Basements | N/A | N/A | N/A |

Q/A

| | | | | |
|----|---|-----------------|-------------|-----|
| | 2 Upper floors | 12 a/c per hour | Natural | MR |
| 5 | Fire Extinguishers | | | |
| | 1 Total Numbers | 16 Nos. | 20 Nos. | MR |
| | 2 Types | ABC & CO2 | ABC & CO2 | MR |
| | 3 ISI Marking | Required | Provided | MR |
| 6 | First-Aid Hose Reel | | | |
| | 1 Total number 1 st floor | 01 | 01 | MR |
| | 2 Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | 3 Nozzle diameter | 05 mm | 05 mm | MR |
| 7 | Automatic Fire Detection & Alarming System | | | |
| | 1 Type of detectors | N/A | Provided | N/A |
| | 2 Location of main panel | N/A | Provided | N/A |
| | 3 Location of repeater panel | N/A | Provided | N/A |
| | 4 Alternate source of power | N/A | Provided | N/A |
| | 5 Hooter's Location | N/A | Provided | N/A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System | | | |
| | 1 Basement | N/A | Provided | N/A |
| | 2 Upper floors | N/A | N/A | N/A |
| | 3 Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | 1 Size of riser/down-comer | 100 mm | 100 mm | MR |
| | 2 Number of hydrants per floor | 01 nos. | 01 nos. | MR |
| | 3 Hose box | 01 nos. | 01 nos. | MR |
| 12 | Yard Hydrants | | | |
| | 1 Total number of hydrants | N/A | N/A | N/A |
| | 2 Hose box | N/A | N/A | N/A |
| 13 | Pumping Arrangement | | | |
| | A Ground level | | | |
| | 1 Discharge of main pump | N/A | N/A | N/A |
| | 2 Head of main pump | N/A | N/A | N/A |
| | 3 Number of main pump | N/A | N/A | N/A |
| | 4 Jockey pump out put | N/A | N/A | N/A |
| | 5 Jockey pump head | N/A | N/A | N/A |
| | 6 Stand by pump output | N/A | N/A | N/A |
| | 7 Stand by pump head | N/A | N/A | N/A |
| | 8 Auto starting/Manual stopping | N/A | N/A | N/A |
| | B Terrace level | | | |
| | 1 Discharge of pump | 450 LPM | 450 LPM | MR |
| | 2 Head of pump | 40 mtr. | 40 mtr. | MR |
| | 3 Power supply | Required | Provided | MR |
| | 4 Auto starting of pump | Required | Provided | MR |
| 14 | Capacity of Water Storage for Fire Fighting | | | |
| | 1 Underground tank capacity | N/A | N/A | N/A |
| | 2 Draw-off connection | N/A | N/A | N/A |
| | 3 Fire service inlet | N/A | N/A | N/A |
| | 4 Access to tank | N/A | N/A | N/A |
| | 5 Over head tank capacity | 20,000 ltr. | 20,000 ltr. | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |

mw

N/8

| | | | | |
|----|--|----------|------------|-----|
| 15 | Exit Signage. | Required | Provided ✓ | MR |
| 16 | Provision of Lifts. | | | |
| | 1 Pressurization of lift shaft | N/A | N/A | N/A |
| | 2 Pressurization of lift lobby | N/A | N/A | N/A |
| | 3 Communication in lift car | N/A | N/A | N/A |
| | 4 Fireman's switch | N/A | N/A | N/A |
| | 5 Lift signage | N/A | N/A | N/A |
| 17 | Stand by Power Supply | Required | Provided | MR |
| 18 | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19 | Fire Control Room | N/A | N/A | N/A |
| | 1 Detector system panel | N/A | N/A | N/A |
| | 2 Flow switch panel | N/A | N/A | N/A |
| | 3 PA system panel | N/A | N/A | N/A |
| | 4 Battery backup | N/A | N/A | N/A |
| | 5 Building floor plan | N/A | N/A | N/A |
| 20 | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

Note: Photos and undertaking enclosed.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and fire fighting system is common.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended please.

M.K. Sharma

Signature of the Inspection Officer
Name :- M.K. Sharma
Designation:- ADO/LN

A.K. Jaiswal
25/07/2022

Signature of the Inspection Officer
Name :- A.K. Jaiswal
Designation:- DO/ED

Dy. CFO (NDZ)

Dir
28/07/2022

C.F.O.
Dir
29/07/2022
Director

P/S B/K

DLF/NAL

Dir
01/08

DO (ED)

Spoken.

Director
Dir
01/08/22

Dir
03/08/2022

DLF

Dir
04/08/2022

D.T.C