

C-42  
7/11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2022/ 382

Dated: 10/8/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Ashirwad Inn Guest House at 70-71, Church Mission Road, Fatehpuri, Delhi -06 comprised of Ground + 03 upper floors: ground floor- (reception + school), 1<sup>st</sup> floor – (school), 2<sup>nd</sup> floor- (trust office), 3<sup>rd</sup> floor- (11 guest rooms), total 11 guest rooms was earlier granted FSC by this department vide letter No. F6/DFS/MS/GH/2019/NDZ/1437 dated 12.07.2019. Now, the premise was re-inspected by the officer concerned of this department on 02.08.2022 in presence of Mr. Bacchan Singh (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy class of “Residential (Sub Division-A-1), Guest House for 11 guest rooms at 3<sup>rd</sup> floor only, with effect from ...10.../8.../2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on ...10/8/22.....at New Delhi by.



(S.K. Dua)

Dy. Chief Fire Officer o/c  
Delhi Fire Service

**Copy to:-**

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2022052511203 dated 25.05.2022.
2. The Licensee, M/S Ashirwad Inn Guest House at 70-71, Church Mission Road, Fatehpuri, Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

- N/17 -

### INSPECTION REPORT

1	Name & address of the building	M/S Ashirwad Inn Guest House, located at 70-71, Church Mission Road, Fatehpuri, Delhi - 06.			
2	Building is comprised of	Ground + 03 upper floors (11 guest room only at 3 <sup>rd</sup> floor)			
3	Type of occupancy	Residential Group A-1			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/GH/2019/NDZ/1437 dated 12.07.2019			
6	Fire safety direction letter no.	Nil			
7	Date of inspection	02.08.2022			
8	Name of the inspecting officers	Sh. Sumit Kumar ADO (SPM)			
9	Name of the designation of officer from the building side	Mr. Bacchan Singh (Manager)			
10	Year of construction	2012			
11	Applicant's letter no.	Online application no. 2022052511203 dated 25.05.2022			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR	
1	<b>Access To Building:</b>				
	Road width	NA	18 mtrs.	NA	
	Gate width	NA	NA	NA	
	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
	<b>A</b>	Number of staircases			
		a Upper floor	02 nos.	02 nos.	MR
		b Basement	NA	NA	NA
	<b>B</b>	Width of staircases			
		a Upper floor	0.80 mtrs.	1.22 & 1.35 mtrs.	MR
		b Basement	NA	NA	NA
	<b>C</b>	Protection of exits			
		a Fire check door	Required	Provided	MR
		b Pressurization	NA	NA	NA
	<b>D</b>	No. of continuous staircases to terrace	NA	NA	NA
	<b>E</b>	Width of corridor	NA	NA	NA
	<b>F</b>	Door size	01 mtrs.	01 mtrs.	MR
3	<b>Compartmentation:</b>				
	<b>A</b>	Fire check door	NA	NA	NA
	<b>B</b>	Sealing of electrical shafts	NA	NA	NA
	<b>C</b>	Fire rating of shaft door	NA	NA	NA
	<b>D</b>	Water curtain	NA	NA	NA
	<b>E</b>	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>				
	<b>A</b>	Basements	30 ACPH	NA	NA
	<b>B</b>	Upper floors	12 ACPH	Natural /Ventilated	MR

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	07 nos.	07 nos.	<b>MR</b>
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	<b>MR</b>
	<b>C</b>	ISI marking	ISI marked	ISI marked	<b>MR</b>
<b>6</b>	<b>First-Aid-Hose Reels:</b>				
	<b>A</b>	Total numbers of each floor	1 nos. at 3 <sup>rd</sup> floor	Provided	<b>MR</b>
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs.	<b>MR</b>
	<b>C</b>	Nozzle diameter	5 mm	5 mm	<b>MR</b>
<b>7</b>	<b>Automatic Fire Detection And Alarming System:</b>				
	<b>A</b>	Type of detectors (CO type)	Required	Provided	<b>MR</b>
	<b>B</b>	Location of main panel	Required	Provided at 3 <sup>rd</sup> floor	<b>MR</b>
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	Required	Provided	<b>MR</b>
	<b>E</b>	Hooters	Required	Provided	<b>MR</b>
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		Required	Provided	<b>MR</b>
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A</b>	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	<b>B</b>	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM	<b>MR</b>
	b)	Head of the pump	30 mtrs.	30 mtrs.	<b>MR</b>
	c)	Power supply	Required	Provided	<b>MR</b>
	d)	Auto starting of pump	Required	Provided	<b>MR</b>

<b>14</b>	<b>Captive Water Storage For Fire Fighting:</b>			
<b>A</b>	Underground tank capacity	NA	NA	NA
<b>B</b>	Draw-off connection	NA	NA	NA
<b>C</b>	Fire service inlet	NA	NA	NA
<b>D</b>	Access to tank	NA	NA	NA
<b>E</b>	Overhead tank capacity	2,500 ltrs.	2,500 ltrs.	<b>MR</b>
<b>15</b>	<b>Exit Signage:</b>	Required	Provided	<b>MR</b>
<b>16</b>	<b>Provision of Lifts:</b>			
<b>A</b>	Pressurization of lift shaft	NA	NA	NA
<b>B</b>	Pressurization of lift lobby	NA	NA	NA
<b>C</b>	Communication in lift car	NA	NA	NA
<b>D</b>	Firemen's grounding switch	NA	NA	NA
<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>	Required	Provided	<b>MR</b>
<b>18</b>	<b>Refuge Area:</b>			
<b>A</b>	Total area	NA	NA	NA
<b>B</b>	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room :</b>			
<b>A</b>	Detector system panel	NA	NA	NA
<b>B</b>	Flow switch panel	NA	NA	NA
<b>C</b>	Pa system panel	NA	NA	NA
<b>D</b>	Battery backup	NA	NA	NA
<b>E</b>	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/GH/NDZ/2022/333 dated 06/05/2022 has been rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/2019/NDZ/1437 dated 12.07.2019 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

*(Signature)*  
03/08/2022

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO/CD)

*(Signature)*  
31/8/22  
~~Dy. C.F.O. (G/2)~~

F.T. please.

*(Signature)*  
04/08/22

ADO (SPM)

F.T. letter is Put up for Signature, Please.

*(Signature)*  
06/08/2022