

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F.6/DFS/MS/BNQT/2022/NDZ/ 46

Dated: 16/8/2022

FIRE SAFETY CERTIFICATE

Certified that M/s The Savour Banquet Hall running at ground floor of the building comprised of basement, stilt, ground plus three upper floors located at 662/10, Shivpuri Main Road, Krishna Nagar Extn., Delhi-110051, owned/occupied by The Savour Banquet was issued FSC vide letter No. F.6/DFS/MS/GH/2018/NDZ/369 dated 06/03/18 (for ground and one upper floor). The premises was re-inspected by the officer concerned of this department on dated 30/07/2022 in the presence of Mr. Puneet Wadhawa and observed that now Banquet Hall is running on ground floor only and all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" for ground floor with effect from 16/8/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 16/8/2022 at New Delhi by


(S. K. DUA)

06/08/22
DY. CHIEF FIRE OFFICER/NDZ

To,

Sh. Vineet Arora,
662/10, Shivpuri Main Road, Krishna Nagar-110051

Copy to: -

The Joint Commissioner of Police (Lic.),
1st Floor Police Station, Defense Colony, New Delhi

MHA ID No. 2022062013229

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

M/32

INSPECTION REPORT

1. Name & address of the building : M/s The Savour Banquet Hall, 662/10, Old C-2, Shivpuri Main Road, Krishna Nagar Extn., Delhi-110051
2. Building is comprised of : Basement + Stilt + Ground +3 upper floor (Banquet Hall running at ground floor only)
3. Type of Occupancy : Assembly
2. Type of Case : Renewal
3. Details of Previous NOC letter : F.6/DFS/MS/GH/2018/NDZ/369 dated- 06/03/18 (for ground and first floor only)
4. Fire Safety direction letter No : NBC-IV
5. Date of Inspection : 30/07/2022
6. Name of the Inspecting officers : ADO Deepak Kumar
7. Name and designation of Officer from the building side : Mr. Puneet Wadhawa.
8. Year of Construction : 2008
9. Applicant's email ID : 2022062013229 dated-09/07/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6m N/A N/A	30m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1 no. 2 nos.	3 nos. 2 nos.	MR MR
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.5 mtr 1.25 mtr	02 mtr. 1.25mtr & 01mtr 1.25 mtr & 0.80 mtr	MR(Accepted earlier) MR(Accepted earlier)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	1 no.	2 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr	02 mtr	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	Required Required N/A N/A N/A	Provided Provided N/A N/A N/A	MR MR N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required Required	Exhaust Ventilated	MR MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 nos. ABC /CO ₂ ISI marked	14 nos. ABC /CO ₂ ISI marked	MR MR MR

V

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPMX2	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No. F.6/DFS/MS/GH/2018/NDZ/369 dated- 06/03/18 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
02/08/2022
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd.)

~~DO(ED)~~

Pl. check composition of Banquet Hall. In previous FSC dated 06/3/22 B/Hall is running on Ground Floor & Ist Floor.

~~ADO/Shahd.~~

Deepak
03/08/2022

Sir,

As per page No. C/57 Owner declared Banquet Hall is running on Ground floor. An Guest House FSC issued vide letter No. F6/DFS/MS/GH/2021/NDZ/456 dt. 21/09/2021 for Ist to III rd floor. Attached in the file on page No. T-70.

~~DO(ED)~~

Put up Ammended I/R + DFA.

Deepak
08/08/2022

~~ADO/Shahd.~~

Sir, Ammended I/R (N/32) and DFA are Re-submitted for your approval pl.

Deepak
12/08/2022
P.T.O