



No. F6/DFS/MS/GH/SZ/2022/ 385

Dated: 17/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24**, comprised of basement, ground floor + 03 upper floors: **basement-** storage. **ground floor-** reception + 05 guest rooms. **1st floor** – 06 guest rooms. **2nd floor-** 06 guest rooms. **3rd floor** –06 guest rooms, was granted FSC by this department vide letter no. F6/DFS/MS/GH/2019/SZ/1479 dated 18.07.2019 for 23 guest rooms. The premises was re-inspected by the officer concerned of this department on 16.08.2022 in presence of Mr. Rajesh Anand (Owner) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the building is fit for occupancy of **Group 'A' (Residential) sub division A-1 (Lodging and rooming), having 23 guest rooms (ground floor-** reception + 05 guest rooms, **1st floor** – 06 guest rooms, **2nd floor-** 06 guest rooms. **3rd floor** –06 guest rooms), with effect from 17/08/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 17/08/2022 at New Delhi by

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
2. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24 : to ensure the occupancy of the building as per the approved plan.
3. The Licensee, M/s Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement shall be used as per BBL/UBBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained there to before occupancy of the same.
10. This FSC is valid for ground +03 upper floors only.
11. The temporary construction on the terrace shall not be used for any purpose..

INSPECTION REPORT

1	Name & address of the building	M/s Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24.		
2	Building is comprised of	Basement + Ground + 03 upper floors Basement – storage Ground floor - reception + 05 guest rooms 1st floor – 06 guest rooms 2nd floor - 06 guest rooms 3rd floor –06 guest rooms Terrace floor – temporary construction pota cabin (closed)		
3	Type of occupancy	Residential. 'Group-A' (Guest House)		
4	Type of case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/GH/2019/SZ/1479 dated 18.07.2019		
6	Fire Safety direction letter no.	Nil		
7	Date of inspection	16.08.2022		
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Rajesh Anand (Owner)		
10	Year of construction	2009		
11	Applicant's letter no.	Online application no. 2022060111846 dated 02.06.2022 and email dated 22.07.2022.		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per Rule 35 (6)	Provided at Site	Remarks MR/NMR
	Access to building			
1	A Road width	6.0 mtrs	7.0 mtrs	MR
	B Gate width	NA	NA	NA
	C Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	A Number of staircases			
	a Upper floor	01 nos.	01 nos	MR
	b Basement	02 nos.	02 nos.	MR
	B Width of staircases			
	a Upper floor	1.2 mtrs	1.25 mtrs	MR (Old Case)
	b Basement	1.2 mtrs	1.20 mtrs & 1.17 mtrs	MR
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	Old case	1 to 1.20 mtrs	MR
	F Door size	1.0 mtr.	1.0 mtr (final exits)	MR
3	Compartmentation			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System.			
	A Basement	Natural/ Mechanical	Exhaust fan	MR
	B Upper floor	Natural/ Mechanical	Exhaust fan	MR

2/24

M's Amby Inn Guest House located at M-13, Lajpat Nagar-II, New Delhi-24

5.	Fire Extinguisher					
	A	Total numbers	06 nos.	06 nos.	MR	
	B	Types	CO ₂ & ABC	ABC type	MR	
	C	ISI marking	ISI marked	Provided	MR	
6	First-Aid-Hose Reels					
	A	Total numbers of each floor	01 nos.	01 nos.	MR	
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR	
	C	Nozzle diameter	5 mm	5 mm	MR	
7	Automatic Fire Detection And Alarming System (required as per clause 7.31.viii, UBBL 2016).					
	A	Type of detectors	CO detectors	Provided	MR	
	B	Location of main panel	At ground floor reception	Provided	MR	
	C	Location of repeater panel	NA	NA	NA	
	D	Alternate source of power	NA	NA	NA	
	E	Hooters	Audible in entire building	Provided	MR	
8	MOEFA		Required	Provided	MR	
9	Public Address System.		Required	Provided	MR	
10	Automatic Sprinkler System.					
	A	Basement	Required	Provided	MR	
	B	Upper floor	NA	NA	NA	
	C	Sprinkler above false ceiling	NA	NA	NA	
11	Internal Hydrants					
	A	size of riser/down-comer	NA	NA	NA	
	B	Number of hydrants per floor	NA	NA	NA	
	C	Hose box	NA	NA	NA	
12	Yard Hydrants.					
	A	Total number of hydrants	NA	NA	NA	
	B	Hose box	NA	NA	NA	
13	Pumping Arrangements.					
	A	Ground Level				
		a	Discharge of main Pump	NA	NA	NA
		b	Head of Main Pump	NA	NA	NA
		c	Number of main pumps	NA	NA	NA
		d	Jockey pump out put	NA	NA	NA
		e	Jockey pump head	NA	NA	NA
		f	Standby pump out put	NA	NA	NA
		g	Standby pump Head	NA	NA	NA
		h	Auto Starting /Manual stopping	NA	NA	NA
		i	Pump house access	NA	NA	NA
	B	Terrace Level				
		a	Discharge of pump	450+180 LPM	450+180 LPM	MR
		b	Head of the Pump	35 mtrs.	35 mtrs.	MR
		c	Power supply	Required	Provided	MR
		d	Auto starting of pump	Required	Provided	MR

0/25

M/s Amby Inn Guest House located at M-13, Lajpat Nagar II, New Delhi-24

14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	5,000 ltrs	Provided	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided (DG)	MR
18	Refuge Area.				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection Of Special Risks, If Any:				
			NA	NA	NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

During the inspection temporary construction at terrace floor found closed by the management and the owner has submitted an undertaking dated 16.08.2022 stating that temporary construction on terrace floor has been closed and shall not be used for any purpose.

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/GH/SZ/2022/497 dated 27.06.2022 from this department has been rectified by the management.

In view of above, the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/2019/SZ/1479 dated 18.07.2019 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

FFI

16/8/22

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

Dy.CFO (SZ)

ADO (M/R)

Fi is put up pls

17/8

Dy. CFO (SZ)

M.S. ell

uploaded
17/8/22