



476

75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI


No. F6/DFS/MS/EH/WZ/2022/ 230

Dated: 10/8/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Bikanervala Foods Private Limited** located at Shop No. 28, GF, FF, SF, Adarsh Bhawan Co-op, West Punjabi Bagh, New Delhi-110026 in a building comprised of Basement + Ground + 03 Upper Floors, Owned/Occupied by M/s. **Bikanervala Foods Private Limited**, was issued FSC vide letter no. F6/DFS/MS/WZ/2019/1198 dated 06/06/2019. The premises was re-inspected by the officer concerned of this department on 27/07/2022 in the presence of Sh. Pushpender (General Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 10/8/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed overleaf.

Issued on 10/8/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The owner/occupier, M/s. Bikanervala Foods Private Limited Located at Shop No. 28, GF, FF, SF, Adarsh Bhawan Co-op. Society, West Punjabi Bagh, New Delhi – 110026.
Online Application ID no. 2022040505611 dated 16/06/2022
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addcp.lic@delhipolice.gov.in)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhwestzone@gmail.com)



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Bikanervala Foods Private Limited Located at Shop No. 28, GF, FF, SF, Adarsh Bhawan Co-op. Society, West Punjabi Bagh, New Delhi- 110026.
2. Type of Occupancy : Assembly at Ground, 1st & 2nd Floor **(The Building Comprised of Basement + Ground + 03 Upper Floors)**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/1198 dated 06/06/2019
5. Fire Safety directives letter No : Nil
6. Date of inspection : 27/07/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Mr. Pushpender (General Manager)
9. Year of Construction : 1997 (As Per MHA Portal)
10. Applicant's letter No. : Online Application 2022040505611 dated - 16/06/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement As per pre insp. report dated 20/05/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mtr	12 mtr Provided	MR
	• Gate width	NA	On Main Road	NA
	• Width of internal road	NR	NR	NR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	Provided	MR
	• Upper Floors	02	Provided	MR
	• Basements			
	b. Width of staircases	Old Case	99cm & 126cm (Ground to 2 nd floor), 59cm (2 nd to 3 rd floor)	MR (Old Case)
	• Upper Floors	Old Case	Provided	MR (Being old case)
	• Basements			
	c. Protection of exits	Required in Basement	Provided	MR
	• Fire check door	NR	NR	NR
	• Pressurization			
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	Old Case	2 exit provided on each floor	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided in kitchen	MR
5	Fire Extinguishers			
	• Total numbers	12	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		30 m required	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		G. Floor	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Old Case	Provided	MR
		NR	Provided	NR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Old Case	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NR	NR
		NR	NR	NR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2 x 450 LPM	Provided	MR
		60 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.		
	• Pressurization of Lift Shaft	NR	NR
	• Pressurization of Lift lobby	NR	NR
	• Communication In lift Car	NR	NR
	• Fireman's Grounding Switch	NR	NR
	• Lift Signage	NR	NR
17	Standby power supply	Required	Provided
18	Refuge Area.		
	➤ Total Area	NR	NR
	➤ Location	NR	NR
19	Fire Control Room		
	• Detector System Panel	NR	NR
	• Flow Switch Panel	NR	NR
	• PA System Panel	NR	NR
	• Batter backup	NR	NR
	• Building Floor Plans	NR	NR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR

The fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/WZ/EH/2022/327 dated 13/05/2022 have been complied.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2019/1198 dated 06/06/2019 renewal under Rule 35 of DFS Rule 2010 is recommended.

DO (west)

SFF
29/7/2022

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

235/ADO/MN
29/7/2022

D.O. (WEST) 598
DATED 29/7/2022

dy
28/7/2022

DO (WZ)

WZ
11/8/2022

AAO/MN Sir, F.T is put up for your perusal & Signature please.

WZ
19/8/2022

SFF
04/8/2022

Uploaded
22/8/22

WZ
11/8/2022