



592

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2022/ 892

Dated: 17/8/2022

FIRE SAFETY CERTIFICATE

Certified that the building of G.D Goenka Public School Located at Sector-10, Dwarka, New Delhi – 110075 comprised of B + G + 4UFs owned/ occupied by **Lakhmi Chand Charitable Society** was issued FSC vide Letter No: F6/DFS/MS/School/2018/SZ/1589 Dated 09/07/2018. The premises was re inspected by the officers concerned of this department on 05/08/2022 in the presence of Mr. Gurmeet S. Pannu (Admin Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Delhi Fire Service Rules 2010 under Delhi Fire Service Act 2007 and that the premises is fit for occupancy class "Educational" Group B with effect from 17/8/22 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/8/22 at New Delhi by.


(Atul Garg)
Director,
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal G.D Goenka Public School Located at Sector-10, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

1. **The lifts shall not be used for any purpose. If the lifts are found being used the FSC shall be null and void.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.


13/8/22

21/26
INSPECTION REPORT

1. Name & address of the building: G.D Goenka Public School Located at Sector-10, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 4 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/1589 Dated 09/07/2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2008/3321 Dated 03/12/2008
6. Date of inspection : 05/08/2022
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Gurmeet S. Pannu (Admin Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : Nil Dated 13/07/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	6 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	6 Nos.	6 Nos.	MR
	• Basements	7 Nos. + 1 Ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 & 1.8 m	Provided	MR (being old case)
	• Basements	1.5 mtr	Provided	MR (being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	04 Nos.	04 Nos. to terrace 1 up to 3 rd & 1 up to 4 th floor	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	01mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



N/97

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c charge	Provided	MR
		12 a/c charge	Natural Ventulation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	22 nos.	Provided	MR
		ABC & CO ₂	Provided	MR
		ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	06 Nos.	Provided	MR
		30 m	Provided	MR
		05 mm.	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		GF	Provided	MR
		Basement	Provided	MR
		Required	Provided	MR
		Appropriate places	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		06 Nos.	Provided	MR
		Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2 X 900 lpm & 1 jockey	Provided	MR
		180 lpm		
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

(Handwritten mark)

N/28

14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts (Lift has been closed)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	DG set	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/1589 Dated 09/07/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The lifts have been closed & shall not be used in future.



Signature of the Inspecting Officer
Name;-Sh Vedpal
Designation DO/SW



Signature of the Inspecting Officer
Name :-Udaivir Singh
Designation ADO/DWK




C.F.O. Hussain
10/8/2018

Director M. J. Singh
11/8/18

