

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/ 233

Dated: 23/8 /2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Match Box** located at Plot No 9-A, 3rd & 4th Floor, Hauz Khas Village, New Delhi 110016 in the building comprised of Ground plus Four upper floor owned / occupied by unit of AVV Hospitality was issued fire safety certificate by this department vide letter no F6/DFS/EH/SZ/2018/2624 dated 06/12/2018 in the name of M/s Out of Box Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 16/08/2022 in the presence of Mr. Amit Panda of the restaurant and that the premises is fit for occupancy class "**Group-D Assembly**" (**Restaurant running at 3rd & 4th floor only**) with effect from 23/8 /2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23 / 8 /2022 at New Delhi by



**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2022081216106 dated 12/08/2022)
2. M/s Match Box at Plot No 9-A, 3rd & 4th Floor, Hauz Khas Village, New Delhi 110016.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. The First & Second floor of the building shall always be clear as seen during the visit and shall not be occupied for any commercial activity.

4-25

93

INSPECTION REPORT

1	Name & Address of the Building	M/s Match Box (A unit of AVV Hospitality) located at Plot No 9-A, 3 rd & 4 th Floor, Hauz Khas Village, New Delhi 110016 Assembly 'Group-D'		
2	Type of Occupancy	Ground plus four upper floor		
3	Building comprised of	Renewal / Name Change		
4	Type of Case	F6/DFS/EH/SZ/2018/2624 dated 06/12/2018		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	16/08/2022		
7	Date of Inspection	Sh. Rajesh Kumar, ADO (BCP)		
8	Name of the Inspecting Officers	Mr. Amit Panda		
9	Name & Designation of Officers from the building side	2001 Restt. is running at 3 rd & 4 th floor of the bldg		
10	Year of construction/ date of conversion	MHA Portal ID 2022081216106 dated 12/08/2022		
11	Applicant letter No.			
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks
1	Access to Building.			
	• Road width	06m	4.5 m + 1.5m	MR (old case)
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02	02	MR
	• Basement floor	-NA-	NA	-NA-
	b. Width of Staircase			
	• Upper floors	Old case	1.50 m & 1.2 m	MR
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	-NA-	NA	MR
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	Required	01 Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	NA	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	NA	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Exhaust fan Provided	MR
5	Fire Extinguishers.			
	• Total numbers	16 Nos	16 Nos	MR
	• Types	ABC / CO2/W.CO2	ABC / CO2/W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR

1426

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooper's location 	4 th floor	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Provided at Terrace (old Case)		
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access 	2280 LPM	Provided	MR
		70m	Provided	MR
		01 Nos	Provided	MR
		180 LPM	Provided	MR
		70m	Provided	MR
		2280 LPM	Provided	MR
		70m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		55,000 Ltrs	55,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector System Panel. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N-27



	• Flow Switch Panel.			
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 466 dated 13/07/2022

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/EH/SZ/2018/2624 dated 06/12/2018, renewal under rule 35 (6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh
18/08/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

F.T.

Dy. CFO (SZ)

[Signature]

ADO (BCP)

AS approved, F.T. letter is put up for
your signature pl

18/08/2022

Dy CFO/2 *[Signature]*

M.S. all

fsc uploaded
24/8/22