



C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव


No. F6/DFS/MS/EH/WZ/2022/214

Dated: 01/08/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. Nando's Restaurant (a unit of M/s. Nandos Karnataka Restaurants Pvt. Ltd.) running at upper ground floor in a building comprised of basement, stilt, upper ground plus three upper floors located at Property No. 25, UGF, NWA, Club Road, Punjabi Bagh West, New Delhi- 110026, owned/occupied by M/s. Nandos Karnataka Restaurants Pvt. Ltd., was granted fire safety certificate by this department vide letter No. F6/DFS/MS/WZ/2019/1364 dated 02.07.2019. The premises was re-inspected by the officer concerned of this department on 27.07.2022 in the presence of Sh. Jaideep Bhaumik (GM) and observed that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class- "Assembly" (Group-D) (**Restaurant at Upper Ground Floor only**) with effect from 01/08/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 01/8/2022 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to:-

1. The Owner / Occupier, M/s. Nando's Restaurant, Property No. 25, UGF, NWA, Club Road, Punjabi Bagh West, New Delhi- 110026
2. The Dy. Health Officer, MCD, West Zone, Rajouri Garden, New Delhi.
3. The Joint Commissioner of Police (Lic.), Police Station Defence Colony, First floor, New Delhi.

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delehlhlic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
8. This FSC is valid for the Restaurant at Upper Ground Floor only.

2/11

### INSPECTION REPORT

1. Name & address of the building: M/s. Nando's Restaurants, Upper Ground Floor, Plot No. 25, NWA, Club Road, Punjabi Bagh West, Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/2019/1364 dated 02.07.2019
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 27.07.2022
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of Officer  
From the building side : Sh. Jaideep Bhaumik, General Manager
9. Year of Construction : 2015-16
10. Applicant's MHA portal ID : MHA Portal ID- 2022021702304

The restaurant is running on upper ground floor in a building comprised of basement, stilt, upper ground plus three upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per Rule 35 (6) of DFS Act	Provided at site	Remarks MR/NMR
1.	Access of building			
	➤ Road width	09 mts	Provided	MR
	➤ Gate width	4.5 mts	Directly accessible from road	MR
	➤ Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits:			
	a. Number of staircases			
	b. Upper floors	2	Provided	MR
	c. Basements	NA	NA	NA
	d. Width of staircases			
	e. Upper floors	2.0, 1.0 mts	2.0 & 1.5 mts	MR
	f. Basements	NA	NA	NA
	g. Protection of exits			
	h. Fire check door	NA	NA	NA
	i. Pressurization	NA	NA	NA
	j. No of continuous staircase to terrace	01	Provided	MR
	k. Width Of Corridor	NA	NA	NA
	l. Door Size	2.0, 1.0 mts	2.0 & 1.0 mts	MR
3.	Compartmentation			
	➤ Fire check door	NA	NA	NA
	➤ Sealing of electrical shafts	NA	NA	NA
	➤ Fire Rating of shaft door	NA	NA	NA
	➤ Water Curtain	NA	NA	NA
	➤ Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	➤ Basements	NA	NA	NA
	➤ Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	➤ Total numbers	06 nos.	Provided	MR
	➤ Types	ABC & CO <sub>2</sub>	Provided	MR
	➤ IS marking	ISI marked	Provided	MR

8/11

6.	First – Aid Hose Reels			
	➤ Total numbers on each floor	01	Provided	MR
	➤ Length of hose reel hose	30 m	Provided	MR
	➤ Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	➤ Type of detectors	NA	Smoke	---
	➤ Location of Main Panel	NA	Provided	---
	➤ Location of Repeater Panel	NA	Provided	---
	➤ Alternate source of power	NA	Provided	---
	➤ Hooters' Location	NA	Provided	---
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	➤ Basements	NA	NA	NA
	➤ Upper Floor	NA	Provided on UGF	NA
	➤ Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	➤ Size of riser/down- comer	100 mm	Provided	MR
	➤ Number of hydrants per floor	01	Provided	MR
	➤ Hose Box	01	Provided	MR
12.	Yard Hydrants			
	➤ Total number of hydrants	NA	NA	NA
	➤ Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	➤ Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	➤ Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	➤ Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	---
	➤ Access to tank	NA	Provided	---
	➤ Overhead Tank capacity	10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA

		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/WZ/2019/1364 dated 02.07.2019, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

D.O. (WEST)-623  
DATED 28/7/2022

*[Handwritten signature]*  
28/7/2022

*[Handwritten signature]*  
28/7/2022

*[Handwritten signature]*  
28/7/2022

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (Moti Nagar)

*[Handwritten signature]*  
West

*[Handwritten signature]*  
29/7/2022

*[Handwritten signature]*  
ADDO/MIN

Sir, F.T is put up for your personal & signature please!

*[Handwritten signature]*  
11/8/2022

*[Handwritten signature]*  
01/08/2022

*[Handwritten signature]*  
ms / ceq

uploaded  
*[Handwritten signature]*  
13/08/2022