

42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2022/SZ/ 894

Dated: 17/8/2022

FIRE SAFETY CERTIFICATE

Certified that the **Sant Nirankari Public School** located at T-23, Malviya Nagar (Khirki Village Road), New Delhi-110017, comprised of **ground plus two upper floors** was issued FSC by this department vide letter No. F.6/DFS/MS/School/2019/SZ/1850 dated 24-09-2019. The premise was re-inspected by the officer concerned of this department on 10/08/2022 in the presence of Mrs. Neelu Bhartiya (Principal) and found that school have complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No 262-362 dated 17.01.2005 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" with effect from 17/8/2022 for a period of **Three years** subject to compliance of the conditions as mentioned below.

Issued on 17/08/2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Sant Nirankari Public School, T-23, Malviya Nagar (Khirki Village Road), New Delhi-110017
2. The Dy. Director of Education (South), Directorate of Education (South District), Govt. of NCT of Delhi, Sector-3, R.K. Puram, New Delhi-110022

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry."

M18

INSPECTION REPORT

1	Name & Address of the Building	Sant Nirankari Public School, T-23, Malviya Nagar (Khirkri Village Road), New Delhi-17		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + Two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2019/SZ/1850 dated 24-09-2019		
6	Fire Safety Directives Letter No	DOE Circular No 262-362 dated 17/01/2005		
7	Date of Inspection	10-08-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Neelu Bhartiya (Principal)		
10	Year of construction	1993		
11	Applicant letter No.	Email dated 04-08-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mts	MR
	• Gate width	-NA-	4.5m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	2 Nos	2 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.08m each	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Two	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI marked	10 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose Reel	01 No	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-

N/90



Sant Nirankari Public School at T-23, Malviya Nagar (Khirki Village Road), New Delhi-110017

The Fire protection systems provided in the building/premise were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2019/SZ/1850 dated 24-09-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh. Rajesh Kumar
16/8/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

Sh. Rajesh Kumar

ADO (BCP)

As approved, f.t. letter is put up for your signature pl

16/8

Dy CFO/SZ

Sh.

MS. cell