

4/28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2022/SZ/898

Dated: 17/8/2022

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Bal Vidyalaya**, Subhash Nagar, New Delhi-110027, comprised of two blocks namely Main Block (Ground floor only) & New Block having ground floor plus one upper floor only owned occupied by Govt. of NCT of Delhi was issued FSC by this department vide letter no. F.6/DFS/MS/School/2019/SZ/1565 dated 01/08/2019. The school building was inspected by the officer concerned of this department on 04/08/2022 in the presence of Sh. Joginder Arora (HOS) and found that Sarvodaya Bal Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....17/8/2022..... at New Delhi.


(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Sarvodaya Bal Vidyalaya,
Subhash Nagar, New Delhi-110027
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/22

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Bal Vidyalaya, Subhash Nagar, New Delhi-110027
2. Building comprised of : Two blocks namely Main Blk (GF) & New Blk (G+1)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/1565 dated 01/08/2019
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 04/08/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers From the building side : Sh. Joginder Arora (HOS)
10. Year of Construction : Before 2019
11. Applicant's letter No. : SBV/SN/2022/183 dated 07/07/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs. N/A	Provided 4.5& 3.4 mtrs. N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03No.'s in NB	Provided	MR
	b. Width of staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m	1.50, 1.50 & 1.50 m	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Class room Door Size	1.0 m	.90/.95/1.10 & 1.07 m in MB & 1.0 & 1.07 m (double door) in NB	MR, being old case in MB & MR in NB
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A	N/A	N/A
		Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	30 no's ABC/CO ₂ type	Provided	M/R
			Provided	M/R
		ISI marked	Provided	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

10

N/A

Fire Con

7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	N/A	N/A	N/A
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	N/A	N/A	N/A
	➢ Head of the pump	N/A	N/A	N/A
	➢ Power Supply	N/A	N/A	N/A
	➢ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A

1

N/24

Fire Control Room

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Battery backup
- Building Floor Plans

N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

20. Special Fire Protection System for Protection of special Risks, if any:

N/A	N/A	N/A
-----	-----	-----

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no.F6/DFS/ MS/School/2019/SZ/1565 dated 01/08/2019 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended Fire Safety Certificate.

R.K. Yadav
Signature of Inspecting Officer

Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

Sh. S/Sir
Dy. C.F.O. (S2)

F.T.
Sh.

A.M. (S/P)

F-T helter is put up for sign please

R.K. Yadav
11/8/2022

Dy. C.F.O. (S2) *Sh.*

MS. Sh.