



4/37

75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/WZ/School/2022/ 911

Dated 18/8/2022

FIRE SAFETY CERTIFICATE

Certified that the **S.J.K Public School**, located at **A-204,205, Raghubir Nagar, New Delhi-110027** comprised of Ground + Three upper floors only owned/ occupied by **S.J.K. Public School** has already issued FSC by this department vide letter No. F.6/DFS/MS/School/2018/WZ/371 dated 07/03/2018. The premises was inspected by officer concern of this department on 02/08/2022 in the presence of Sh. Baljeet Kaur (Admin) and observed that all the fire prevention and fire safety arrangements provide in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular dated 01/03/2011/NBC (Part-IV) and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from ...18/8/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 conditions printed overleaf.

Issued on 18/8/2022 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Principal, S.J.K Public School, located at A-204,205, Raghubir Nagar, New Delhi-110027.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : S.J.K Public School Located at A-204,205, Raghubir Nagar, New Delhi-110027.
2. Type of Occupancy : Educational (Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/371 Dated: 07/03/2018
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011/NBC (Part-IV)
6. Date of inspection : 02/08/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of officers from the building side : Baljeet kaur (Admin)
9. Year of Construction : 1990 (As per prev. insp. report dated- 07/02/2018)
10. Applicant's letter No. : Email dated 28/06/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011/As per prev. insp. report dated-28/12/2017	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts	Provided 6 mts	MR
	• Gate width	4.5 mts	On Road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02 Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mts	1.50mtr x 1 & 0.70 mts x 1	MR (Old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1 m	Provided	MR (old case)
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	08	Provided 10 Nos	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

4/19

16

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	➤ Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/20

10

Provision of Lifts.

• Pressurization of Lift Shaft	N/A	N/A	N/A
• Pressurization of Lift lobby	N/A	N/A	N/A
• Communication In lift Car	N/A	N/A	N/A
• Fireman's Grounding Switch	N/A	N/A	N/A
• Lift Signage	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
----	-----------------------------	----------	----------	----

18 Refuge Area.

➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A

19 Fire Control Room

• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Batter backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A

20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A
----	--	-----	-----	-----

Note: - General requirement for schools as per Director of education circular dated 01/03/2011.

1. Escape routeClear
2. LPG cylinders in laboratoriesNil
3. Electric wiring ...Conduit Wiring.....MCB and ELCB.....Electric circuit.....
4. Electric meter board.....Not under the staircase.....
5. Basement use as per BBL 1983.....NA.....
6. Emergency telephone no. board.....Displayed.....
7. Generator set.....Nil.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/WZ/371 dated 07/03/2018 renewal under rule 35 of the Delhi Fire Service rule 2010, is recommended.

(Signature)
08/08/2022

(Signature)
08/08/2022

227/ADOMN
08/08/2022

(Signature)
12/08/2022

DFS (WZ)

(Signature)
16/08/2022

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN)

D.O. (WEST)/SFF
DATED...12/08/22

ADOMN

Sir, F.T is put up for your kind perusal & signatures please.

(Signature)
17/08/2022