

474
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/2022/SZ/ 913

Dated: 26/8/2022

FIRE SAFETY CERTIFICATE

Certified that the **BLUE BELLS SCHOOL INTERNATIONAL** at Kailash, New Delhi 110048 comprised of Basement, Ground plus three upper Floors owned/occupied by **Blue Bells Education Society** was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2005/2000 Dated 28/09/2005. The said premises was re-inspected by officer concerned of this department on 18/08/2022 in presence of Mrs. Manju Sethi and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 26/8/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 26/8/2022 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to: -

1. M/s BLUE BELLS SCHOOL INTERNATIONAL (Blue Bells Education Society) at Kailash, New Delhi 110048.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
3. The Joint Director (R&E), DDA, Building Section, Vikas Sadan, INA, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. In any case, the Additional / temporary rooms at 3rd floor of the building shall not be used for conducting classes and or any other educational activities, as undertaking submitted by the school management

INSPECTION REPORT

1	Name & Address of the Building	M/s BLUE BELLS SCHOOL INTERNATIONAL (Blue Bells Education Society) at Kailash, New Delhi.		
2	Type of Occupancy	Educational, Group- B (School)		
3	Building Comprised of	Basement, Ground plus 03 Upper Floors.		
4	Type of Case	Old Case		
5	Details of Previous NOC	F6/DFS/MS/2005/2000 Dated 28/09/2005		
6	Fire Safety Directives Letter No	12 basic fire prevention & fire Safety measures		
7	Date of Inspection	18-08-2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Manju Sethi (Principal)		
10	Year of construction	1993		
11	Applicant letter No	Outdoor diary no 4058 Dated 03/08/2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	9 mtr	MR
	• Gate width	Accessible	6 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	Provided 06 nos	MR
	➤ Basement floor.	Required	Provided 02 nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.25 mtr	1.16, 1.14, 1.70, 1.30, 1.21 & 1.39 mtr	MR (Old Case)
	➤ Basement floor	1.25 mtr	1.52 m & 1.49 m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided in basement	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided in basement	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	24 Nos	MR
	• Types	ABC	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	03 Nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			

N/22

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	Provided	MR
		Required	03 No's	MR
		Required	03 No's	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	04 No's	MR
		Required	04 No's	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	1620 LPM	Provided	MR
		60 m	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		60 m	Provided	MR
		1620 LPM	Provided	MR
		60 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450LPM	900 LPM	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	50,000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-

NA-
NA-
A-
1-

H/23



	<ul style="list-style-type: none"> Flow switch panel PA system panel Battery backup Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 338 dated 22/06/2022. The management of school has also given undertaking that the temporary structure at terrace level has been removed and the temporary rooms at 3rd floor will not be used for conducting classes.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as per bare minimum requirements of Fire Safety and Fire prevention Act 1987 & as required under the rules, the FSC issued vide letter F6/DFS/MS/2005/2000 Dated 28/09/2005, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

F.T.

Sh. Rajesh Kumar
23/8/22

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ)

Sh.
22/8

ADO/BCP

As approved, F.T. letter is put up for your signature pl.

1/16
25/8/2022

Dy CFO/SZ

Sh.