

C/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2022/ School/ W2 1905


Dated: 18/8/2022

FIRE SAFETY CERTIFICATE

Certified that the **Chand Ram Public (Sr. Sec.) School** located at **Nangal Thakran, Delhi-110039** is running on Single Block of Ground and First Floor only in a building comprised of Two Block of Ground + One upper floor owned/occupied by **Chand Ram Public (Sr. Sec.) School** was issued FSC by this department vide letter No. **F6/DFS/MS/2019/1258 dated 12/06/2019**. The premises was inspected by the officer concerned of this department on 16-08-2022 in the presence of **Sh. Pawan Prakash(Manager)** and observed that all the fire prevention and fire safety arrangement as provided in the permises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Education** with effect from 18/8/2022 For a period of **three years** and subject to compliance of the conditions mentioned below.

Issued on 18/8/2022 at New Delhi

Yours faithfully


(Dharampal Bhardwaj)
Dy Chief Fire Officer
Delhi Fire Service



Copy to: -

1. Director of Education Govt. of NCT, Delhi, Old Secretariat, Delhi
- 2 The Principal, **Chand Ram Public Sr. Sec. School, Nangal Thakran, Delhi-110039**

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
2. Loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. Second Block of Ground and First Floor shall not be used for school activity.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Chand Ram Public Sr. Sec. School , Nangal Thakran , Delhi-110039
2. Type of Occupancy : Educational
3. Building comprised : Two Blocks (Ground+ One upper floor)
4. Type of Case : Renewal (Single Block of Ground+ First Floor Only)
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2019/1258 Dated-12/06/2019
6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
7. Date of inspection : 16/08/2022
8. Name of Inspecting Officer : ADO R.K Sinha
9. Name and designation of officers
From the building side : Sh. Pawan Prakash (Manager)
10. Year of Construction : 1998
11. Applicant's letter No. : E Mail id , Dated-06/08/2022

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--------------------------|------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 6.0 m | 6.0 m | MR |
| | • Gate width | 4.5 m | 3.60 m | MR(old case) |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | NA | NA | NA |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | NA | NA | NA |
| | • Upper Floor | 1.50 m | 1.10 m ×2 | MR (old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.00 m | 80 cm | MR (old case) |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | NA | NA |



| | | | | |
|-----|--|--|--|--|
| | <ul style="list-style-type: none"> Upper floors | 12 a/c per hour | Natural Ventilated | MR |
| 5. | Fire Extinguishers <ul style="list-style-type: none"> Total numbers Types IS marking | 09 ABC Yes | 10 ABC Yes | MR MR MR |
| 6. | First-Aid Hose Reels <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 30 m 5 mm | Provided 30 m 5 mm | MR MR MR |
| 7. | Automatic fire detection and alarming system <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | NA NA NA | NA NA NA | NA NA NA |
| 11. | Internal Hydrants <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA NA NA | NA NA NA | NA NA NA |
| 12. | Yard Hydrants <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13. | Pumping Arrangements <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | NA NA NA NA NA NA NA NA | NA NA NA NA NA NA NA | NA NA NA NA NA NA NA |

Handwritten signature

| | | | | |
|-----|---|---|--|----------------------------------|
| | <ul style="list-style-type: none"> ➤ Pump House Access | NA | NA | NA |
| | <ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | - 450 lpm 40 m NA - NA | - Provided Provided NA - NA | - MR MR NA - NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | NA NA NA NA 2500 ltrs Required | NA NA NA NA Provided Provided | NA NA NA NA MR MR |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | NA NA | NA NA | NA NA |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

My

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management has rectified the shortcomings issued vide letter no. F6/DFS/MS/School/2022/WZ/429 dated 26/07/2022.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no F6/DFS/MS/2019/1258.

DO/DO

[Signature]
ADO (BW)
16/8/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW

[Signature]
16/08/2022

DO/DO

[Signature]
16/8/22

~~ADO/BW~~ F-1 letter in put up for sign please

[Signature]
ADO (BW)
17/8/22

DO/DO

[Signature]
18/8/22

MS/MS