

L-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2022/SZ/ 516

Dated: 28/8/2022

FIRE SAFETY CERTIFICATE

Certified that Gargi Sarvodaya Kanya Vidyalaya located at Green Park, Extn. New Delhi 110016 comprised of Ground + One upper floor (01 Block) & Ground Floor only (02 Blocks) owned/occupied by Directorate of Education, Govt. of NCT of Delhi was issued FSC by this department vide letter no. F6/DFS/MS/School/2019/SZ/1795 dated 18/09/2019. The premises was re-inspected by officer concerned of this department on 10/08/2022 in presence of Mrs. Manisha Malhotra (V.Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class “**Educational Building Group – B**” with effect from 28/8 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 28/8/22 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. Gargi Sarvodaya Kanya Vidyalaya located at Green Park, Extn. New Delhi 110016.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL–2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL–2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.”

N/21

INSPECTION REPORT				
1	Name & Address of the Building	Gargi Sarvodaya Kanya Vidyalaya, Green Park, Extn. New Delhi 110016		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 01 upper floor (01 Block) & Ground floor (02 Blocks)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1795 dated 18/09/2019 for G+1 (01 Blocks) & GF only (03 Blocks)		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	10-08-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Manisha Malhotra (V.Principal)		
10	Year of construction	1962		
11	Applicant letter No.	351/GSKV/2022 dated 05-07-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	5 mtr	5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Two	Three	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.90m	1.50m, 1.40m & 1.37m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 Nos	Provided	MR
	e) Width of corridor	1.50 mtr	Provided	MR
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI marked	20 Nos	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/28

7	<ul style="list-style-type: none"> Length of hose-reel hose Nozzle Diameter Automatic fire detection & alarming system.	-NA-	-NA-	-NA-	
		<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
		<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
		<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
		<ul style="list-style-type: none"> Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8	MOEFA	-NA-	Provided	-NA-	
9	Public Address System	-NA-	-NA-	-NA-	
10	Automatic Sprinkler System <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
11	Internal Hydrants. <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
12	Yard Hydrants. <ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
13	Pumping arrangements. <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
14	Captive water storage for fire fighting. <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts. <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	
17	Standby Power Supply	-NA-	-NA-	-NA-	
18	Refuge Area <ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-	
		-NA-	-NA-	-NA-	

N/28

[Handwritten mark]

	• Location			
19	Fire Control Room.	-NA-	-NA-	-NA-
	• Detector system panel	-NA-	-NA-	-NA-
	• Flow switch panel	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building /premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular, the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/1795 dated 18/09/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

Dy. CFO (SZ) *[Handwritten signature]*
[Handwritten signature]
M.S. cell

[Handwritten signature]

As approved, F.T. letter is put up for your signature.

[Handwritten signature]

Dy CFO/SZ *[Handwritten signature]*
[Handwritten signature]
M.S. cell