

C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/2022/School/WZ/ 924

Dated: 30/8 /2022

FIRE SAFETY CERTIFICATE

Certified that the **M.C.D Pry Boys/Girls School, B-Block, Shahbad Dairy, Delhi-42**, comprised of **02 Blocks, Ground + 01 upper floors** owned/occupied by **M.C.D Pry Boys/Girls School** was granted FSC by this department vide letter No. **F6/DFS/MS/2019/School/1544** dated **26.07.2019**. The premises was re-inspected by the officer concerned of this department on **02.08.2022** in the presence of **Smt. Veena Devi (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no 3298-3398** dated **01.03.2011** and the building/ premise is fit for occupancy Group B Educational with effect from **30/8/2022** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **30/8/2022** at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

DTC
CHY

Copy to: -

1. The Deputy Commissioner, Narela Zone, North Delhi Municipal Corporation, Opp. Police Station, Narela, Delhi, 110040.
2. The Principal, M.C.D Pry Boys/Girls School, B-Block, Shahbad Dairy, Delhi-42.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

11/15

INSPECTION REPORT

1. Name & address of the building : M.C.D Pry Boys/Girls School, B-Block, Shahbad Dairy, Delhi-42.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (02 Blocks, Gr. + 01 upper floors)
4. Details of Previous NOC : F6/DFS/MS/2019/School/1544 dated;26.07.2019
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 02.08.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Ranbir Singh (Teacher In-charge)
9. Year of Construction : 2001
10. Applicant's letter No. : OD No.3169 Dated-07.07.2022

C.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5m NA	Accessible 4.3m NA	MR MR(old case) NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	03	Block-I-02 Block-II-01	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases	1.5m	Block-I-1.95m Block-II-1.5m	MR
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	2.05m	MR
	f. Door Size	1m	1.12m double door	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural Ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	07nos ABC/CO2 ISI marked	08nos ABC-08 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	NA NA NA	NA NA NA	NA NA NA

Spec
Prote
The fire pr
time of insp
Keen

	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	p	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA

Special Fire Protection System for Protection of special Risks, if any:


NA

NA

NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F6/DFS/MS/2019/School/1544 dated 26.07.2019** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



15/8/22

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

~~DO (NW)~~



08/08/2022

By C/O (W2)


17/8/22

ADO Rohini

FT letter is put up for kind perusal and
signature please.


24/8/22

~~DCO (W2)~~


24/8/22

not use