

10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


No.F6/DFS/MS/School/NDZ/2022/928

Dated: 30/8/22

FIRE SAFETY CERTIFICATE

Certified that the **The Bengali Senior Sec. School** located at **22-A, Shyam Nath Marg, New Delhi- 110054**, comprised of **Two Blocks 1. (Ground + first floor) & 2. (ground floor only)** owned/ occupied by the Bengali Senior Sec. School was granted FSC by this department vide letter no.F6/DFS/MS/School/2019/NDZ/935 dated 03.05.2019. The premises was re-inspected by the officer concerned of this department on 25.07.2022 in the presence of Sh. Arun Ghosal (Chairman) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 that the building is fit for occupancy, **(Group-B) "Educational Building"** with effect from 30/8/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 30/8/22 at New Delhi by


(S. K. Dua)
Dy. Chief Fire Officer o/l
Delhi Fire Service
23/8

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, The Bengali Senior Sec. School at 22-A, Shyam Nath Marg, New Delhi- 110054.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

| | | |
|----|---|---|
| 1 | Name and address of the building | N.D.M.C. Primary Boys School at Hamilton Road, Kashmere Gate, Delhi - 06. |
| 2 | Type of occupancy with details of floors: | Educational Building Group -B (Ground + one upper floor) |
| 3 | Type of case | Renewal (Old Case) |
| 4 | Details of previous FSC | F6 DFS/MS School/2018/580 dated 04.04.2018 |
| 5 | Fire safety directives no. | NA |
| 6 | Date of inspection: | 10.08.2022 |
| 7 | Name of the inspecting officer: | Sumit Kumar, ADO (SPM) |
| 8 | Name and designation of the officer from the building side: | Supervisor |
| 9 | Year of construction: | 1950 |
| 10 | Reference letter no.: | Letter no. nil dated 27.07.2022 |

| S. No | Minimum Standards on fire Prevention and fire safety requirements U R 33 | As per Education Circular | Provide at site | Remarks MR/NM/R |
|----------|--|---------------------------|-----------------------------------|-----------------|
| 1 | Access to Building | | | |
| A | Road width | Approachable | 40 mtrs. From motable road | MR |
| B | Gate width | NA | NA | NA |
| C | Width of internal roads | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| A | No. of Staircase: | | | |
| | a) Upper floor | 02 nos. | 03 nos. | MR |
| | b) Basements | NA | NA | NA |
| B | Width of the Staircase: | | | |
| | a) Upper floor | 1.50 mtr. | 1.20 mtr. & 0.80 mtr. & 0.80 mtr. | MR |
| | b) Basements | NA | NA | NA |
| C | Protection of Exits | | | |
| | a) Fire check door | NA | NA | NA |
| | b) Pressurization | NA | NA | NA |
| D | No. of continuous staircase to terrace: | NA | NA | NA |
| F | Width of the corridor | NA | NA | NA |
| E | Door size | 1 mtr. | 1 mtr. | MR |
| | Compartmentation: | | | |
| 3 | | | | |
| A | Fire check doors | NA | NA | NA |
| B | Sealing of electrical shafts | NA | NA | NA |
| C | Fire rating of shaft doors | NA | NA | NA |
| D | Water curtain | NA | NA | NA |
| E | Fire dampers | NA | NA | NA |
| | Smoke management System: | | | |
| 4 | | | | |
| A | Basements | 30 ACPH | NA | NA |
| B | Upper floors | 12 ACPH | NA | NA |
| 5 | Fire extinguishers | | | |
| A | Total numbers | 04 nos. | 05 nos. | MR |
| B | Types | Co2 & ABC | Provided | MR |
| C | ISI marking | Required | Provided | MR |

| | | | | |
|-----------|---|----|----|----|
| 6 | First Aid Hose reel | | | |
| A | Total no. at each floor | NA | NA | NA |
| B | Length of Hose Reel | NA | NA | NA |
| C | Nozzle diameter | NA | NA | NA |
| 7 | Automatic Fire Detection and Alarm System (ADAS) | | | |
| A | Type of Detectors | NA | NA | NA |
| B | Location of main Panel | NA | NA | NA |
| C | Location of Repeater Panel | NA | NA | NA |
| D | Alternate power Source | NA | NA | NA |
| E | Hooter's location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System | NA | NA | NA |
| 10 | Automatic Sprinkler System | | | |
| A | Basement | NA | NA | NA |
| B | Upper Floor | NA | NA | NA |
| C | Sprinklers above false ceiling | NA | NA | NA |
| 11 | Internal hydrants | | | |
| A | Size of the riser/down comer | NA | NA | NA |
| B | No. Of hydrants per floor | NA | NA | NA |
| C | Hose box | NA | NA | NA |
| 12 | Yard Hydrants | | | |
| A | Total no. of hydrants | NA | NA | NA |
| B | Hose box | NA | NA | NA |
| 13 | Pumping arrangements | | | |
| A | Ground Level | | | |
| | a) Discharge of main pump | NA | NA | NA |
| | b) Head of main pump | NA | NA | NA |
| | c) Number of main pump | NA | NA | NA |
| | d) Discharge of jockey pump | NA | NA | NA |
| | e) Head of jockey pump | NA | NA | NA |
| | f) Discharge of Standby pump | NA | NA | NA |
| | g) Head of Standby pump | NA | NA | NA |
| | h) Auto starting/ manual stopping | NA | NA | NA |
| B | Terrace Level | | | |
| | a) Discharge of terrace pump | NA | NA | NA |
| | b) Head of terrace pump | NA | NA | NA |
| | c) Alternate power supply | NA | NA | NA |
| | d) Auto starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for Fire Fighting | | | |
| A | Underground tank capacity | NA | NA | NA |
| B | Draw off connection | NA | NA | NA |
| C | Fire Service Inlet | NA | NA | NA |
| E | Access to tank | NA | NA | NA |
| D | Overhead tank capacity | NA | NA | NA |
| 15 | Exit Signage | NA | NA | NA |
| 16 | Provision of lift | | | |
| A | Pressurization of lift shaft | NA | NA | NA |
| B | Pressurization of lift lobby | NA | NA | NA |
| C | Communication in lift car | NA | NA | NA |
| D | Fireman switch | NA | NA | NA |
| E | Lift signage | NA | NA | NA |
| 17 | Standby Power Supply | NA | NA | NA |

| | | | | |
|--|-----------------------------|----|----|----|
| 18 Refuge Area | | | | |
| A | location | NA | NA | NA |
| B | Total area | NA | NA | NA |
| 19 Fire Control Room | | | | |
| A | Fire Detection System panel | NA | NA | NA |
| B | Flow switch panel | NA | NA | NA |
| C | P A system panel | NA | NA | NA |
| D | Battery backup | NA | NA | NA |
| E | Building floor plan | NA | NA | NA |
| 20 Special Fire Protection for special risk if any: | | | | |
| | | | | NA |

The Fire Protection System provided in the school were tested, checked and random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required as per Director of Education Circular dated 01.03.2011, FSC issued vide letter in. F6/DFS/MS/School/2018/580 dated 04.04.2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

Sumit Kumar
16/08/2022

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO/CD
Del
16/8/22
Dy. C.F.O. (ND2)

F.T. please.
KVP
17/08/22

ADO (SPM)

F.T. letter is Put up for Signature, Please.

~~*Dy. C.F.O. (ND2)*~~
F.R. wing

KVP
23/08/22

Sumit Kumar
23/08/2022