

FORM 'F'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2022/ RL65/373

Dated: 31/08/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Maa Vindhyvasini Sewa Sansthan Located at, HAF, Pocket 2, Sector - 17, Dwarka, New Delhi - 110075 comprised of Basement + Stilt / Ground + 2 Upper Floors was issued FSC vide Letter No F6/DFS/MS/2018/SZ/2626 Dated 06/12/2018. The premises was re inspected by the officer concerned of this department on 08/08/2022 in the presence of Sh. Surinder Dhar Dwevedi (President) and found that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group - D "Assembly" with effect from 31/08/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31-8-2022 at New Delhi by.


(Sunil Choudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Joint Director (Building)DDA,Vikas Sadan, INA, Delhi-110023
2. Sh. Surinder Dhar Dwevedi (President) Maa Vindhyvasini Sewa Sansthan Located at, HAF, Pocket 2, Sector - 17, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

21/18

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/SZ/2022/177 dated 19/01/2022 are complied

INSPECTION REPORT

1. Name & address of the building: Maa Vindhyaasini Sewa Sansthan Located at, HAF, Pocket 2, Sector – 17, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Assembly Building "D" (Temple)
3. Type of Case : Renewal Basement, Stilt/Ground+02 upper floors
4. Details of previous NOC : F6/DFS/MS/2018/SZ/2626 Dated 06/12/2018
5. Fire Safety directives L. No. : F6/DFS/MS/BI/2013/374 dated 24/01/2013
6. Date of inspection : 08/08/2022
7. Name of the Inspecting Officer : Udai vir Singh ADO/DWK
8. Name and designation of Officer
from the building side : Sh. Surinder Dhar Dwevedi (President)
9. Year of Construction : 2015
10. Applicant's letter No. : Email dated 25/07/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	30 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper floors	2 m	1.77 mtr Basement to 2 nd floor, 1.5 mtr stilt to 1 st floor	MR(Old case)
	• Basements	2 m	1.70 mtr	MR(Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m	Provided	MR(Old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

M/B

4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	1620 lpm	Provided	MR
	➤ Head of the pump	35 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

21/22

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 litres	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts		Provided	MR
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	NA	NA
18.	Refuge Area		DG set 62.5 KVA	MR
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher near electric panel	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2018/SZ/2626 Dated 06/12/2018 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *ADO/DWA*

Uday Vir Singh
25/12/22
dyerof/sz
dy
A DO/DWA

Sir pt letter is put up for sig plc
dyerof/sz
M.S.
25/12/22