



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/INDL/NDZ/2022/ 377

Dated : 01/09/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Fashion Maker International at Plot no. 87, FIE, Patparganj Ind. Area, Delhi-110092 comprised of Basement + Ground + 01 Upper floors owned/occupied by M/s Fashion Maker International was granted FSC by this department vide letter No. F6/DFS/MS/INDL/2019/NDZ/1449 dated 16/07/2019. The premises was inspected by the officers concerned of this department on 25/08/2022 in the presence of Mr. Sanjay Mishra (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Industrial Building" (Group G) with effect from ~~01/09/2022~~ for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ~~01/09/2022~~ at New Delhi by.


(S.K Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Mr. Sanjay Mishra,
M/s Fashion Maker International,
Plot no. 87, FIE, Patparganj Ind. Area, Delhi-92.



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Basement shall be used strictly as per Building By-Laws.



- N/B -

INSPECTION REPORT

Azadi Ka
Amrit Mahotsav

1. Name & address of the building : M/s Fashion Maker International, Plot no. 87, FIE, Patparganj Ind. Area, Delhi-92
2. Type of occupancy : Industrial Building
(Basement + Ground + 01 Upper floor)
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/INDL/2019/NDZ/1449 dated 16/07/2019
5. Fire safety directives No. : NBC Part-IV
6. Date of inspection:- : 25/08/2022
7. Name of the inspecting officer : Sh. A.K. Jaiswal (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side : Mr. Sanjay Mishra (Manager)
9. Year of construction : 1996
10. Applicant's letter No : nil dated 14/07/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement BBL 1983 / NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	20 mtr.	MR
	2) Gate width	4.50 mtr.	4.50 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	02 No.	02 No.	MR
	B. Width of staircase			
	1. Upper floors	1.25 m	1.50 mtr & 1.25 mtr.	MR
	2. Basements	1.25 m	1.50 mtr & 1.25 mtr.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 no.	02 no.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR

Mav



- 2/9

75
Azadi Ka
Amrit Mahotsav

6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	01 no.	01 no.	MR
	3) Hose box each floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	i) Pump house access	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM ✓	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

M

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltr.	15,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/INDL/2019/NDZ/1449 dated 16/07/2019, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

M.K.S
 Signature of the Inspecting Officer
 Name :- M.K. Sharma
 Designation :- ADO (LN)

A.K. Jaiswal
 Signature of the Inspecting Officer
 Name :- A.K. Jaiswal
 Designation :- DO (ED)

Dy. CFO (NDZ)

F.T. please.

Kirp 30/08/22

ADO (LN)

F.I. letter is put up for sig. p

Dy. CFO (NDZ)

Kirp 01/09/22

M.K.S 01/9

F.P. wing