

439

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2022/244

Dated 02/9/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s BARUSH (A Unit of Akashdeep hospitality) located at C-38, First floor, Connaught place, New Delhi comprises of Ground + 02 upper floor and Restaurant running at first floor only. The premises was inspected by Officers concerned of this department on 26/08/2022 in the presence of Manager and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D restaurant at first floor only**, with effect from 02/9/2022 for period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 02/9/2022 at New Delhi by.


(Atul Garg)
DIRECTOR

Delhi Fire Service
9/8/22

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Joint Commissioner of Police(Lic) , 1st floor,PS Defence Colony , New Delhi. Online No. 2022051310199 dated 17.05.2022 & mail id akashdeephospitality@gmail.com dated 22.08.2022.
3. The Manager,
M/S BARUSH (A Unit of Akshdeep hospitality) C-38, First floor, Connaught place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.
10. This Fire Safety Certificate is Valid for restaurant at first floor only.

04/15
INSPECTION REPORT

1. Name & address of the building: M/S **BARUSH** (A Unit of Akshdeep hospitality) located at C-38, First floor, Connaught place, New Delhi. Gr+02 upper floor
2. Type of occupancy: - Assembly Occupancy Group-D Restaurant at First floor only
3. Type of case:- New
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 26/08/22
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Manager
9. Year of construction:- 1950(old heritage)
10. Applicant's letter No:- No. 2022051310199 dated 17.05.2022 & e mail < akashdeephospitality @ gmail.com dated 22.08.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per BBL-1983 & NBC part-4	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02nos	02 nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25mtr & .75mter	.90 & 1.50 meter	MR(restaurant is running before enactments of UBBL-2016 i.e from Feb. 2016
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2x1.5 mtr	2x1.50mtr	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR



4/16

5.	Fire Extinguishers			
	1) Total numbers	02 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement common with hotel			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

MR
MR
MR

M

14.	Captive Water Storage for Fire Fighting common with hotel			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

Further, the applicant has submitted the copy of license issued on date 19 January 2016 (C-34) from Jt. commissioner of police (Lic) & NDMC (C-31) under 48 seats through e-mail placed on opposite side. This shows that the restaurant is running before the enchantment of UBBL-2016.

In view of above, if approved, we may consider the width of staircase as per BBL-1983 i.e 1.25 & .75 meter. Accordingly, the fire protection arrangements provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety as required under the Rules, if approved, we may issue the fire safety certificate to the said restaurant.

Signature of the Inspecting Officer

Rajinder Atwal
29/8/22

Name:- Rajinder Atwal
Designation:-DO (CD)

Signature of the Inspecting Officer

Sh. Ravinder Singh
29/8/22

Name: - Sh. Ravinder Singh
Designation: ADO (CC)

Dy. C.F.O. (C-34)

C.F.O.
31/8/2022

Director/AD
11/9/22

R.V.P.
30/8/22

FTP/IS

DOT/CD

P.T.O