

C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2022 | 141

Dated: 10 / 02 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Kanya Vidyalaya No.02**, located at **Punjabi Bagh, New Delhi-110026 (School ID-1515023)(New Building)**, comprised of Ground Floor + 03 Upper Floors owned/occupied by **Govt. Sarvodaya Kanya Vidyalaya No.2** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and verified by the officer concerned of this department on 28/01/2022 in the presence of Sh. Sanjay Chauchan (Project Manager) and found that the building / premises is fit for the occupancy class **“Educational” Group B** with effect from 10/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 10/02/2022 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
09/02/2022

Copy to:

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya No. 02, located at Punjabi Bagh, New Delhi-110026 (School ID-1515023)
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT 10/6

1. Name & address of the building: Sarvodaya Kanya Vidyalaya, No. 2, Punjabi Bagh, New Delhi-110026. **(School ID-1515023)**
2. Type of Occupancy : Educational (Ground Floor + 03 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 28/01/2022
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer from the building side : Sh. Sanjay Chauchan
9. Year of Construction : 2021
10. Applicant's letter No. : 54 (SPS School)/PWD Edu. Sub- Divn M1-1(N)/2021-22/179 dated 10.09.2021

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC/UBBL-16 | Provided at site | Remarks MR/NMR |
|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|----------------------------------|----------------------------|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | 6m 4.5 m NA | Provided Provided NA | MR MR NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements | 2 NA | Provided NA | MR NA |
| | b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements | 1.5m each NA | Provided NA | MR NA |
| | c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization | NA NA | NA NA | NA NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | 1.5m | Provided | MR |
| | f. Door Size | 2 x 1.20 m | Provided | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | NA NA | NA NA | NA NA |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 12 nos. ABC & CO2 ISI marked | Provided Provided Provided | MR MR MR |

| | | | | |
|-----|----------------------------------------------|-------------|----------|----|
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 2 | Provided | MR |
| | • Length of hose reel hose | 30 m | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down- comer | NR | Provided | NR |
| | • Number of hydrants per floor | NR | Provided | NR |
| | • Hose Box | NR | Provided | NR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | NA | NA | NA |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | NA | NA | NA |
| | ➤ Discharge of pump | 450 lpm | Provided | MR |
| | ➤ Head of the pump | 40 m | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for firefighting: | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 Ltrs | Provided | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fire man's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| | | | | |
|-----|--------------------------------------------------------------------------|----|----|----|
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2021/670 dated 22/12/2021 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

~~D O (west)~~

~~S/S~~
01/02/2022
Sarabjeet Singh
ADO (MN)

~~HP~~
01/02/2022

~~DCFO (WZ)~~

~~[Signature]~~
07/07/2022

D-1 ADO (MN)
01/02/2022
D.O. (WEST)/321
DATED. 2/2/2022

~~CSO~~

~~[Signature]~~
42



~~[Signature]~~
4/02/2022

~~[Signature]~~

~~[Signature]~~
08/02/2022

~~ADO (MN)~~ Sir F.T is put up for your personal & signature please!

~~[Signature]~~
09/02/2022