

427

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/EH/2022/N02/239

Dated: 30/8/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Hard Rock café (A Unit of JSM JG Foods LLP) at 1st & 2nd floor located at show room no. 01 Atma Ram Mansion Scindia House, Janpath Road Cannought Place, New Delhi building comprised of Ground + 2 Upper Floors and restaurant at first floor & second floor only, was earlier granted fire safety certificate in the name & style to M/s The Tourist Restaurant (A Unit of Hilarious hospitality Pvt ltd.) vide letter no. F6/DFS/MS/EH/2016/277 dated 16.08.2016. Now, the premises was re-inspected by officers concerned of this department in presence of Mr. Shivam Choudhary on dated 18.08.2022 and found that the said premises, has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the building / premises, is fit for occupancy class **Assembly Building(Group D), Restaurant at 1st & 2nd floor only** with effect from 30/8/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued...30/8/2022...at New Delhi by.



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic) , 1st floor, PS Defence Colony, New Delhi Online ID No. 2022080815953 dated 08/08/22.
2. The Executive Engineer, NDMC, Palika Kendra, New Delhi: to ensure the occupancy as detailed above.
3. The Manager, M/s Hard Rock café (A unit of JSM JG Foods LLP) at 1st & 2nd floor located at show room no. 01 Atma Ram Mansion Scindia House, Janpath Road Cannought Place, New Delhi.

Condition for the validity of Fire Safety Certificate

1. This FSC is valid for restaurant at first & second floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration shall strict be prohibited.

416

INSPECTION REPORT

- 1. Name & address of the building:- M/s Hard Rock café (A unit of JSM JG Foods LLP) at 1st & 2nd floor located at show room no. 01 Atma Ram Mansion Scindhia House, Janpath Road Cannought Place, New Delhi
- 2. Type of occupancy:- Group – D Assembly Building
Gr. + 2 upper floor but restaurant at first & second floor
- 3. Type of case:- Renewal
- 4. Details of previous FSC:- F6/DFS/MS/EH/2016/277 dated 16.08.2016
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 18/08/22
- 7. Name of the inspecting officer:- Sh. Rajinder Atwal DO/CD
Sh. Ravinder Singh ADO/CC
- 8. Name & designation of officer
From the building side:- Sh. Mr Shivam Coudhary
- 9. Year of construction:- Old Heritage.
- 10. Applicant's letter No:- 2022080815953 dated 08/08/22.

Old case renewal

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ B.B.L	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 & 1.25 mtr.	2 Nos. 1.20 to 1.30 mtr. each	MR(old case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2.mtr, 1.12mtr.	2.mtr, 1.12mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A

✓

	2) Upper floors	12 a c per	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	05 Nos.	07 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors.	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A



	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, we may renew the fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2016/277 dated 16.08.2016 under rule 35 of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature /approval please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

[Signature]
 Name: - Sh. Rajinder Atwal
 Designation :- DO/CD

[Signature]
 Name :- Ravinder Singh
 Designation:- ADO (CC)

[Signature] F.T. please.
[Signature]
 25/08/22

[Signature] As copy provided, etc put up for kind perusal and signature P.
[Signature]

[Signature] F.T. wing
[Signature]
 25/08/22

[Signature]
 26/8/22