

C-21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/ 934
FIRE SAFETY CERTIFICATE

Dated: 1/9/22

Certified that the **Holy Cross School**, Najafgarh, New Delhi-110043, comprised of two blocks namely Block-A & Block-B. Block-A having ground plus two upper floors and tin shed on third floor & Block-B having ground floor plus three upper floors. Both blocks are interconnected at ground floor & second floor level only, owned/occupied by Holy Cross School was issued NOC by this department vide letter no. F.6/MS/DFS/2019/SZ/956 dated 09/05/2019. The School building was re-inspected by the officer concerned of this department on 12/08/2022 in the presence of Sister Maria Fernends (Principal) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the school building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on.....1/9/22..... at New Delhi.


(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER

Rep.

Copy to:-

1. The Principal, Holy Cross School, Najafgarh, New Delhi-110043.

2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/14

INSPECTION REPORT

- 1. Name & address of the building
- 2. Building comprised of
- 3. Type of Occupancy
- 4. Type of Case
- 5. Details of Previous NOC
- 6. Fire Safety directives letter No
- 7. Date of inspection
- 8. Name of Inspecting Officer
- 9. Name and designation of officers
From the building side
- 10. Year of Construction
- 11. Applicant's letter No.

Holy Cross School, Najafgarh, New Delhi-110043
 2 blocks, A Block having G+2 & tin shed on third floor & B block having G+3 upper floors. Both blocks are interconnected at ground floor & second floor level only
 Educational
 Renewal
 F.6/ MS/DFS/2019/SZ/956 dated 07/05/2019
 N/A
 08/08/2022
 A D O R K Yadav
 Sister Maria Fernends
 Before 2006
 Nil dated 18/07/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per previous FSC issued dt. 07/05/2019	Provided at site	Remarks MR/NMR
1.	Access to building <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (06 mtrs) 4.5 mtrs N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper Floors • Basements 	02 No 's in each block N/A	02 no 's in Blk-A & 02 no 's in Blk-B N/A	M/R N/A
	b. Width of staircases <ul style="list-style-type: none"> • Upper Floor • Basements 	1.5 m each N/A	1.40 & 1.45 m in Blk-A & 1.50 & 1.30m in Blk-B N/A	M/R old accepted N/A
	c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required N/A	Provided N/A	M/R N/A
	e. Width of Corridor	1.0 m	1.10 m (Single door)	M/R old accepted
	f. Class Room Door Size			
3.	Compartmentation <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	20 no's	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

M/15

6.	First-Aid Hose Reels	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 no 's in Block-A & 01 no in Blk-B	Provided	MR
			30 m	Provided	MR
			5 mm	Provided	MR
7.	Automatic fire detection and alarming system	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA		N/A	N/A	N/A
9.	Public Address System		N/A	N/A	N/A
10.	Automatic Sprinkler System	<ul style="list-style-type: none"> Basment Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			450 LPM (02 no 's)	Provided	MR
			40 m	Provided	MR
			Required	Provided	MR
			Required	Provided	MR
14.	Captive Water Storage for fire fighting	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			5000 ltrs in each block	4000 ltrs in Blk-A & 5000 ltrs in Blk-B	MR being old case
15.	Exit Signage.		Required	Provided	MR

4

17.
18.

N/16

MR
MR
MR

		No Lift		
	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/MS/DFS/2019/SZ/956 dated 07/05/2019 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
13/8/2022
Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South-West)

21/8/22
F.T.

Dy CPO (SZ)

ADD/1/15/1

E T letter & put up for sign, please

Dy CPO (SZ)

M.S. All

21/8/22